



Certificate of Compliance

Certificate: 2531731

Master Contract: 157123

Project: 80118970

Date Issued: 2022-06-28

Issued To: Precision Digital Corporation
233 South Street
Hopkinton, Massachusetts, 01748
United States

Attention: Scott Ewen

The products listed below are eligible to bear the CSA Mark shown

Issued by: Tim McCoy
Tim McCoy



PRODUCTS

CLASS 2258 02 - PROCESS CONTROL EQUIPMENT for Hazardous Locations

**Class I, Div. 1, Groups B, C, D; Class II, Div. 1, Groups E, F, G; Class III Div 1:
Ex db IIC; Zone 21 Ex tb IIIC T90°C:**

Model **PD8-865-BCD-EE-FF-GGGGGGGGG** Modbus Snooper Meters; power/input: see table;

-55 Deg. C ≤ Tamb. ≤ +60 Deg. C; Temperature Code T6;

-55 Deg. C ≤ Tamb. ≤ +65 Deg. C; Temperature Code T5;

Enclosure Type 4X & IP66 / IP68

Models	Ratings
PD8-865	85-265 Vac, 50/60 Hz, 90-265 Vdc, 15 VA max, or 12-24 Vac, 50/60 Hz, 12-36 Vdc, 10 VA max



Certificate: 2531731
Project: 80118970

Master Contract: 157123
Date Issued: 2022-06-28

Part number	Code/Type reference			
PD8	Model Prefix (Precision Digital)			
	AAA	Meter Type		
	865	Modbus Snooper		
		B	Power	
		6	85-265 Vac, 90-265 Vdc	
		7	12 - 24 Vac, 12 - 36 Vdc	
		C	Display	
		R	Red LED	
			D	Output
			2	2 Relays
			5	2 Relays & Aout(s)
			7	4 Relays & Aout(s)
			EE	Transmitter
			06	4-20 mA output
			16	4-20 mA output and 24 Vdc Transmitter
			FF	Enclosure
			AL or None	Aluminum Enclosure
			SS	Stainless Steel Enclosure
			GGGGGGGGG	Cosmetic Modifications
			XXXXXXXXXX	Optional alphanumeric combination to indicate a cosmetic variation, conduit entry configuration and firmware revisions.



Certificate: 2531731
Project: 80118970

Master Contract: 157123
Date Issued: 2022-06-28

-Model **PD8-154-BCD-E-FF-GGGGGGGGGG** and **PD8-158-BCD-E-FF-GGGGGGGGGG** Alarm Annunciators;
 power/input: see table;
 -55 Deg. C ≤ Tamb. ≤ +60 Deg. C; Temperature Code T6;
 -55 Deg. C ≤ Tamb. ≤ +65 Deg. C; Temperature Code T5;
 Enclosure Type 4X & IP66 / IP68

Models	Ratings
PD8-154,	85-265 Vac, 50/60 Hz, 90-265 Vdc, 20 VA max, or
PD8-158	12-24 Vac, 50/60 Hz, 12-36 Vdc, 6 VA max

Part number	Code/Type reference	
PD8	Model Prefix (Precision Digital)	
	AAA	Meter Type
	154	4-Point Alarm Annunciator
	158	8-Point Alarm Annunciator
	B	Power
	6	85-265 Vac, 90-265 Vdc
	7	12 - 24 V ac, 12 - 36 Vdc
	C	Display
	R	Red LED
	D	Output
	2	2 Relays
	E	Transmitter
	0	None
	1	24 Vdc Transmitter
	FF	Enclosure
	AL or None	Aluminum Enclosure
	SS	Stainless Steel Enclosure
	GGGGGGGGG	Cosmetic Modifications
	XXXXXXXXXX	Optional alphanumeric combination to indicate a cosmetic variation, conduit entry configuration and firmware revisions



Certificate: 2531731
Project: 80118970

Master Contract: 157123
Date Issued: 2022-06-28

Model **PD8-6AAA-BCD-EE-FFFFFFFF** Process Meter, **PD8-7AAA-BCD-EE-FFFFFFFF** Temperature Meter; power/input:
 -55 Deg. C ≤ Tamb. ≤ +60 Deg. C; Temperature Code T6;
 -55 Deg. C ≤ Tamb. ≤ +65 Deg. C; Temperature Code T5;
 Enclosure Type 4X & IP66 / IP68

Models	Ratings
PD8-6xxx, PD8-7xxx	85-265 Vac, 50/60 Hz, 90-265 Vdc, 30 VA max, or 12 or 24 Vdc, 15 VA max

Part number	Code/Type reference	
PD8	Model Prefix (Precision Digital)	
	AAAA	Meter Type
	6xxx	Process (voltage, current and/or pulse)
	7xxx	Temperature (TC and RTD)
	B	Power
	6	85-265 Vac, 90-265 Vdc
	7	12 or 24 Vdc (field selectable)
	C	Display
	R	Red LED
	H	High intensity red LED
	D	Output
	0	None
	1	Open collector(s)
	2	2 Relays
	3	Analog output(s)
	4	4 Relays
	5	2 Relays & Aout(s)
	6	6 Relays & Aout(s)
	7	4 Relays & Aout(s)
	8	8 Relays & Aout(s)
	EE	Enclosure
	AL or None	Aluminum Enclosure
	SS	Stainless Steel Enclosure
	FFFFFFFF	Cosmetic Modifications
	XXXXXXXXXX	Optional alphanumeric combination to indicate a cosmetic variation, conduit entry configuration and firmware revisions



Certificate: 2531731
Project: 80118970

Master Contract: 157123
Date Issued: 2022-06-28

Model **PD8-765-BCD-EE-FF-GGGGGGGGG** Temperature Meters; power/input: see table;
 -55 Deg. C ≤ Tamb. ≤ +60 Deg. C; Temperature Code T6;
 -55 Deg. C ≤ Tamb. ≤ +65 Deg. C; Temperature Code T5;
 Enclosure Type 4X & IP66 / IP68

Models		Ratings
PD8-765	-6(R,X)0-00 -6(R,X)2-00	85-265 Vac, 50/60 Hz, 90-265 Vdc, 8 VA max
PD8-765	-6(R,X)0-10 -6(R,X)2-10 -6(R,X)3-00 -6(R,X)3-10 -6(R,X)3-20	85-265 Vac, 50/60 Hz, 90-265 Vdc, 20 VA max
PD8-765	-7(R,X)0-00 -7(R,X)2-00 -7(R,X)3-00	12-24 Vac, 50/60 Hz, 12-36 Vdc, 20 VA max

Part #	Code/Type reference	
PD8	Model Prefix (Precision Digital)	
	AAA	Meter Type
	765	Temperature Meter
	B	Power
	6	85-265 Vac, 90-265 Vdc
	7	12 - 24 Vac, 12-36 Vdc
	C	Display
	R	Red LED
	X	Large 1.2" LED
	D	Output
	0	None
	2	2 Relays
	3	Analog output(s)
	5	2 Relays & Aout(s)
	EE	Transmitter Power Supply
	00	None
	10	24 V
	20	2 x 24 V
	FF	Enclosure
	AL or None	Aluminum Enclosure
	SS	Stainless Steel Enclosure
	GGGGGGGGG	Cosmetic Modifications
	XXXXXXXXXX	Optional alphanumeric combination to indicate a cosmetic variation, conduit entry



Certificate: 2531731
Project: 80118970

Master Contract: 157123
Date Issued: 2022-06-28

								configuration and firmware revisions
--	--	--	--	--	--	--	--	--------------------------------------

Conditions of Acceptability:

1. All power supplies below 36 V and all signal input circuits must be supplied from a Class 2 Certified power supply.
2. Model number may be followed by up to an additional 9-digit alphanumeric combination in the form “-XXXXXXXXXX” to indicate a cosmetic variation, conduit entry configuration and firmware revisions.
3. A seal is required within 18 inches of the enclosure, as part of the CSA Certified Enclosure.
4. When the IME component enclosure 8117 is used in the final assembly, the ambient range is -40° to 60°C/65°C

APPLICABLE REQUIREMENTS

C22.2 No. 25-1966	Enclosures for Use in Class II, Groups E, F and G Hazardous Locations
C22.2 No. 30-M1986	Explosion-Proof Enclosures for Use in Class I Hazardous Locations
CAN/CSA-C22.2 No. 94-M91	Special Purpose Enclosures
CAN/CSA C22.2 No. 14-2018	Industrial Control Equipment
CAN/CSA-C22.2 No. 60079-0:11	Electrical apparatus for explosive gas atmospheres - Part 0: General requirements
CAN/CSA-C22.2 No. 60079-1:11	Electrical apparatus for explosive gas atmospheres - Part 1: Flameproof enclosures "d"
CAN/CSA-C22.2 No. 60079-31	Explosive atmospheres — Part 31: Equipment dust ignition protection by enclosure “t”

MARKINGS

The manufacturer is required to apply the following markings:

- Products shall be marked with the markings specified by the particular product standard.
- Products certified for Canada shall have all Caution and Warning markings in both English and French.

Additional bilingual markings not covered by the product standard(s) may be required by the Authorities Having Jurisdiction. It is the responsibility of the manufacturer to provide and apply these additional markings, where applicable, in accordance with the requirements of those authorities.

The products listed are eligible to bear the CSA Mark, without any adjacent indicators, indicating that products have been manufactured to the requirements of Canadian Standards.

Markings for the Model PD8 Series appear on the following CSA Accepted Adhesive Nameplates:

- Type ILS-320 manufactured by Industrial Labeling Systems, White Polyester
- Type ILS-324 manufactured by Industrial Labeling Systems Metalized Polyester
- Type T/C-329 manufactured by Royal Label, White or Silver Polyester with L-23 adhesive



Certificate: 2531731
Project: 80118970

Master Contract: 157123
Date Issued: 2022-06-28

- Type T/C-387 manufactured by Advanced Labelworx, Inc., White or Silver Polyester with L-23 adhesive
 - Type Dataplate 668 manufactured by F.B. Johnston Group,
- Alternatively, markings may be found permanent on a 0.5 mm thick metal nameplate secured with fasteners.

The following marking details appear:

- Manufacturer's name: "Precision Digital Corporation", or CSA Master Contract Number "157123", adjacent to the CSA Mark in lieu of manufacturer's name.
- Model number: As specified in the PRODUCTS section, above.
- Electrical ratings: As specified in the PRODUCTS section, above.
- Ambient temperature rating: As specified in the PRODUCTS section, above.
- Manufacturing date in MMY format, or serial number, traceable to year and month of manufacture.
- Enclosure ratings: As specified in the PRODUCTS section, above.
- The CSA Mark, as shown on the Certificate of Conformity.
- Hazardous Location designation: As specified in the PRODUCTS section, above (may be abbreviated).
- Temperature code: As specified in the PRODUCTS section, above.
- The statement: "WARNING: DO NOT OPEN WHEN AN EXPLOSION ATMOSPHERE MAY BE PRESENT" and "AVERTISSEMENT: NE PAS OUVRIR SI UNE ATMOSPHERE D'EXPLOSION PEUT ETRE PRESENTE", or equivalent.
- Ingress Rating: As specified in the PRODUCTS section, above
- Special Purpose Enclosure Rating: As specified in the PRODUCTS section, above
- The statement: "Install conduit seals within 18 in. (450 mm) of enclosure" or equivalent
- The statement: "Wiring in this compartment may reach 90°C in an ambient of 65°C" or equivalent
- The statement: "All input circuits must be derived from a Class 2 Certified power supply" or equivalent

Notes:

Products certified under Class C225802 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 2531731

Master Contract: 157123

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
80118970	2022-06-28	Evaluation for revision to 2531731 (last update 80041290) to update model numbers. Includes revision to DWG DW2169 Rev D. Update was to add the "8" to make the series the "PD8" Series
80041290	2020-12-16	Evaluation to update CSA Certificate Report 2531731 to add the EC700 and EX700 Series component enclosures from CSA Certificate Report 80011200, Certificate 80055209; update to the lower end temperature rating from -40C to -55C based on the alternate enclosure ratings of -55C; nomenclature and mode code changes not affecting certification; addition of routine dielectric factory test
70006553	2014-07-22	Evaluation for update of report 2531731 to investigate XP testing previously conducted with possible revision to the markings specifying seal within 18 inches for all installations. Any testing deemed required will be additional.
2531731	2012-08-27	Original model certification of PD8 Series, programmable controllers for Hazardous Locations