# PD6907 Ex-Proof & I.S. Loop-Powered Feet & Inches Meter Instruction Manual



- Fully-Approved Explosion-Proof & Intrinsically Safe Loop-Powered Feet & Inches Meters
- 4-20 mA Input Displayed with ±0.02% of Full-Scale Accuracy
- 1.5 Volt Drop (4.7 Volt Drop with Backlight)
- Top Display: Five 7-Segment Digits, FT-IN & Fractions, 0.7" (17.8 mm)
- Bottom Display: Eight 14-Segment Alphanumeric Characters, 0.4" (10.2 mm)
- Displays Level in Feet & Inches up to 999 Feet, 11 & 15/16 Inches
- Display Input in Two Different Scales Simultaneously Great for Level
- 20-Segment Bargraph Standard
- Display Mountable at 0°, 90°, 180°, & 270° (No Tools Required)
- CapTouch Through-Glass Button Programming with Normal and Delayed Modes
- Loop-Powered Backlight with Red Backlight for Alarm Conditions
- (2) Open Collector Outputs Standard; Assignable to Pulse, Alarm, Timer, or Stopwatch
- (2) Optional Loop-Powered Solid-State Relays; Assignable to Alarm, Control, Timer, or Stopwatch
- Stopwatch & Timer Functions to Drive Relays & Open Collectors
- Optional Isolated 4-20 mA Analog Output
- Relay Pump Alternation Based on Level and Runtime
- Display Relay Runtime & Cycle Count via Relay Info Menu
- Round Horizontal Tank Function; Just Enter Diameter & Length
- 32-Point Linearization
- Free PC-Based MeterView XL USB Programming Software
- HART<sup>®</sup> Protocol Transparent
- Enable and Disable Backlight from Menu
- Operating Temperature Range: -40 to 75°C (-40 to 167°F)
- Installation Temperature Range: -55 to 75°C (-67 to 167°F)
- Conformal Coated PCBs for Dust & Humidity Protection
- Password Protection
- UL Listed as Explosion-Proof / Dust Ignition-Proof / Flame-Proof
- CSA Certified as Explosion-Proof / Dust Ignition-Proof / Flame-Proof
- ATEX and IECEx Certified as Intrinsically Safe and Explosion-Proof
- Flange for Wall or Pipe Mounting; Loop for Stainless Steel Tag; Holes for Tamper-Proof Seal
- Explosion-Proof Aluminum & Stainless Steel Enclosures with 3/4" or M20 Connections
- 3-Year Warranty

**PRECISION DIGITAL CORPORATION** 

233 South Street • Hopkinton MA 01748 USA Tel (800) 343-1001 • (508) 655-7300 www.predig.com



# **The Complete PD6900 Series**

# VantageView+

**Plastic Enclosures - General Purpose** 



PD6907-GP-PL 4-20 mA Input Feet & Inches Meter



PD6908-GP-PL 4-20 mA Input Process Meter



PD6928-GP-PL 4-20 mA Input Flow Rate/Totalizer



PD6938-GP-PL Pulse Input Flow Rate/Totalizer



### Aluminum Enclosures - Hazardous Area Approved



PD6907-HA-AL 4-20 mA Input Feet & Inches Meter



PD6908-HA-AL 4-20 mA Input Process Meter



PD6928-HA-AL 4-20 mA Input Flow Rate/Totalizer



PD6938-XX-AL Pulse Input Flow Rate/Totalizer

### Stainless Steel Enclosures - Hazardous Area Approved



PD6907-HA-SS 4-20 mA Input Feet & Inches Meter



PD6908-HA-SS 4-20 mA Input Process Meter



PD6928-HA-SS 4-20 mA Input Flow Rate/Totalizer



PD6938-XX-SS Pulse Input Flow Rate/Totalizer

# Table of Contents

-	
Display	
General	
Enclosure	
Input	
Common Open Coll	ector & Relay Specifications
Open Collector Out	puts
Solid-State Relays.	
4-20 mA Transmitte	r Output
On-Board Digital In	put
MeterView XL Softw	/are
<b>Compliance Information</b>	on
Electromagnetic Co	mpatibility
	provals
	formity
Safety Information	-
Unpacking	
•	
Connections	
Display & Options M	Nodules
	g
	•
	iring
	ole
	ring
	0 mA) Connections
	ections
	onnections
	Connections
	Itput Connections
	ng
•••••••••••••••••••••••••••••••••••••••	
CapTouch Buttons	s Delay
	buch Buttons
	Tips & Troubleshooting
	ramming Software
-	and Status Indicators
	& Messages
Setting Numeric V	
	nput (INPUT)
	sses and Units
	hits ([USTOM)
Scaling Example.	
	Features (DISPLAY)
	ineering Units (LNIT도) imal Point (코드다가)
	ing Commas on the Bottom Display ([[]MMR)
Configuring the Di	splay (30TT0M)
Programming the	Bargraph (JARGRAPH)

Programming the Outputs (DUTPUT)	38
Open Collector Outputs (OPEN EOLLEETR)	39
Solid-State Relay Outputs (RELRY)	44
Isolated 4-20 mA Output (H20 mA)	50
Output Manual Control (EDNTROL)	50
Advanced Features Menu (AIV ANCE)	51
Advanced Process Variable Setup (日北/ 日北/)	52
Low-Height Cutoff (EUTOFF)	57
Noise Filter (FILTER)	
Enabling Password Protection (PASSWR])	
Programmable Function Keys User Menu (USER)	58
Tare (TARE)	
Changing System Settings (5Y5TEM)	
Meter Operation	
CapTouch Buttons Operation	62
CapTouch Buttons	
	62
CapTouch Buttons	<b> 62</b> 62
CapTouch Buttons CapTouch Button Tips & Troubleshooting	62 62 63
CapTouch Buttons CapTouch Button Tips & Troubleshooting Function Keys Operation	62 62 63 63
CapTouch Buttons CapTouch Button Tips & Troubleshooting Function Keys Operation Digital Input Operation	62 62 63 63 63
CapTouch Buttons CapTouch Button Tips & Troubleshooting Function Keys Operation Digital Input Operation Maximum/Minimum Readings	62 63 63 63 63
CapTouch Buttons CapTouch Button Tips & Troubleshooting Function Keys Operation Digital Input Operation Maximum/Minimum Readings Runtime & Cycle Count (INF[])	62 63 63 63 63 63
CapTouch Buttons CapTouch Button Tips & Troubleshooting Function Keys Operation Digital Input Operation Maximum/Minimum Readings Runtime & Cycle Count (INFI) Changing PV2 Engineering Units	62 63 63 63 63 63 63
CapTouch Buttons CapTouch Button Tips & Troubleshooting Function Keys Operation Digital Input Operation Maximum/Minimum Readings Runtime & Cycle Count (INF[]) Changing PV2 Engineering Units Troubleshooting Reset Meter to Factory Defaults	62 63 63 63 63 63 64 64
CapTouch Buttons CapTouch Button Tips & Troubleshooting Function Keys Operation Digital Input Operation Maximum/Minimum Readings Runtime & Cycle Count (INFI) Changing PV2 Engineering Units Troubleshooting	

# **Table of Figures**

Figure 1. Enclosure Dimensions – Front View	19
Figure 2. Enclosure Dimensions – Side View	
Figure 3. Enclosure Dimensions – Top View	
Figure 4. Connector Labeling for PD6907-HA-##-LNN	
Figure 5. Connector Labeling for PD6907-HA-##-L2N	
Figure 6. Connector Labeling for PD6907-HA-##-L3N	
Figure 7. Connector Labeling for PD6907-HA-##-L5N	
Figure 8. 4-20 mA Input Connection without Backlight	
Figure 9. 4-20 mA Input Connection with Backlight	
Figure 10. Digital Input Connections	
Figure 11. 4-20 mA Output Connections	
Figure 12. Solid-State Relay Connections	
Figure 13. Open Collector Output Connections	



Watch the Loop-Powered Meters Video



Click or Scan

#### Disclaimer

The information contained in this document is subject to change without notice. Precision Digital Corporation makes no representations or warranties with respect to the contents hereof; and specifically disclaims any implied warranties of merchantability or fitness for a particular purpose.

#### **A** CAUTION

• Read complete instructions prior to installation and operation of the meter.

#### **WARNINGS**

- This product is not recommended for life support applications or applications where malfunctioning could result in personal injury or property loss. Anyone using this product for such applications does so at his/her own risk. Precision Digital Corporation shall not be held liable for damages resulting from such improper use.
- Failure to follow installation guidelines could result in death or serious injury. Make sure only qualified personnel perform the installation.
- For Explosion-Proof / Dust Ignition-Proof / Flame-Proof applications, never remove the meter cover in explosive environments when the circuit is live.
- Cover must be fully engaged to meet for Explosion-Proof / Dust Ignition-Proof / Flame-Proof requirements.

### 

Cancer and Reproductive Harm - www.P65Warnings.ca.gov

#### **Limited Warranty**

Precision Digital Corporation warrants this product against defects in material or workmanship for the specified period under "Specifications" from the date of shipment from the factory. Precision Digital's liability under this limited warranty shall not exceed the purchase value, repair, or replacement of the defective unit. See Warranty Information and Terms & Conditions on <u>www.predig.com</u> for complete details.

#### **Registered Trademarks**

All trademarks mentioned in this document are the property of their respective owners.

© 2024 Precision Digital Corporation. All rights reserved.

# Introduction

The PD6907 ProtEX+ loop-powered explosion-proof & intrinsically safe feet and inches meters can be installed virtually anywhere to provide convenient and informative display of any 4-20 mA signal. They can operate down to -40°C and be installed in areas that get as cold as -55°C, however the display will cease functioning. One of the most convenient features of these instruments is their dual-line display. The top display is used to display level in feet and inches while the 8-character alphanumeric bottom display can be used to display a tag or custom message. Another common setup is to display the input in feet and inches on the top display and in another scale on the bottom display (such as the volume in gallons). The bottom display line uses 14-segment alphanumeric characters that provide much clearer indication of tags, units, or alarm messages than 7-segment characters do.

Further enhancing the display on these instruments is a 20-segment bargraph that also includes a numeric value of the percentage the bargraph represents.

These loop-powered meters can be installed virtually anywhere because they get their power from the 4-20 mA loop and therefore require no separate power source. And they only drop 1.5 V (4.7 V with backlight), so they add very little burden to the loop. Additional features that allow these instruments to be installed virtually anywhere include a NEMA 4X, IP68 explosion-proof enclosure, an operating temperature range of -40 to  $167^{\circ}$ F (-40 to  $75^{\circ}$ C), conformally coated PCBs, and a backlit LCD that can be read in bright sunlight or dimly lit areas.

The ProtEX+ carries all major approvals including:

- UL Listed as Explosion-Proof / Dust Ignition-Proof / Flame-Proof.
- CSA Certified as Explosion-Proof / Dust Ignition-Proof / Flame-Proof
- ATEX and IECEx Certified as Intrinsically Safe / Explosion-Proof

Free, PC-based, MeterView XL software that connects to the meter via a micro USB cable is available for programming and setup of the meters. For more details, see the <u>MeterView XL manual</u>. Four CapTouch through-glass buttons are available to operate the instrument without removing the cover.

All models come equipped with two open collector outputs and a digital input. There are also models available with two solid-state relays and isolated 4-20 mA analog output options. The open collector outputs are useful for alarm indication. The digital input can be used to acknowledge the relays, to start/stop a timer/stopwatch, and more. The relays can be programmed for alarm indication, on/off control, or pump alternation.

# **Key Features**



### 2X More Informative Display

The PD6907 display offers a 50% larger display area and is twice more informative than previous generations of loop-powered explosion-proof meters. Featuring an alphanumeric dual-line display and a 20-segment bargraph, reading and understanding process values is easy and intuitive. The addition of status indicators provides a quick glance at alarm conditions, relays, process trends, and more. Predefined display units give users even more display flexibility. Plus, the high contrast backlit LCD display is readable from far away and under various lighting conditions.



### **Backlight Turns Red on Alarm**

When an alarm occurs, the display can be programmed to turn red, flash, and display an alarm indicator **A**. In addition, a unique custom alarm message for each of the two relays and two open collectors can be displayed on the bottom display. These features can be activated even if no relay or open collector is connected.

# CapTouch Through-Glass Buttons


The PD6907 is equipped with four capacitive sensors that operate as through-glass buttons so that it can be operated without removing the cover (and exposing the electronics) in a hazardous area. CapTouch buttons are designed to work under any lighting condition and to protect against false triggering. They can be disabled for security via a switch on the display module.



CapTouch buttons have two modes of operation: Normal and Delayed. Delayed mode prevents accidental trigger of the buttons. In the Delayed mode, the buttons enter into a low sensitivity state (sleep) and they ignore quick button presses after 20 seconds of inactivity. To wake up the buttons, press and hold any button for more than 2 seconds, the buttons respond normally.

# Feet & Inches Display with Bargraph

Designed for users that prefer to read level in feet and inches instead of a decimal format, the PD6907 can display level up to 999FT 11IN & 15/16 on the top display. The bottom display can toggle between a tag (Tank 4) and units (Gallons), and if dual-scale mode is enabled, then the input can be displayed in a different scale such as volume (17,500).



# **Predefined and Custom Units**

The meter has six available preprogrammed unit classes when programming PV2: volume, height, temperature, pressure, weight, and rate. When the desired unit class or unit of measure within a class is not available, a custom unit may be programmed.

# **14-Segment Characters**

Notice how much better letters like "T", "N" and "K" appear as 14-segment characters on the bottom display vs. 7-segment characters found on other meters.



### Password Protection

A password can be set up for programming security to prevent unauthorized changes to the programmed parameter settings.

# Enable / Disable Backlight

The backlight may be enabled or disabled using the System - Backlight menu. The backlight is enabled by default, but the input must be wired appropriately for the backlight to function. See *Enabling or Disabling the Backlight* (IREKLITE) on page 61 for details.

### **Multiple Outputs**

- Two open collector outputs (standard)
- Two solid-state relays 🖬 🖬 (optional)
- One 4-20 mA output (optional)

The open collector outputs and relays generally operate in the same manner, with the major exception being the open collectors are not available for pump alternation and the relays are not available with pulse features. The open collectors and relays can be controlled either automatically or manually.

The isolated analog output signal can be configured to represent the process variable (PV1, PV2, or retransmit). It can also be reverse scaled such that the meter's high calibration value outputs 4 mA and the meter's low calibration outputs 20 mA.



# Free MeterView XL Programming Software

The fastest and easiest way to program the meter is using the free Meterview XL programming software. This software greatly simplifies the programming process and allows the user to save configuration files for later use.

The meter connects to the PC via a provided micro-USB cable and is powered by the USB connection, so no additional power is needed during programming.



# Wide Viewing Angle

The window and display module have been optimized to provide a wide viewing angle of approximately  $\pm 40^{\circ}$ ; nearly twice that of the competition. Plus, the display module can be rotated in 90° increments providing added mounting flexibility.

### **Modern and Practical Enclosure**

The PD6907 NEMA 4X, IP68 enclosure provides serious protection from the elements, high impact, corrosion, and electrical interference. Plus, the extensive worldwide agency approvals allow it to be installed virtually anywhere.



Aluminum or Stainless Steel Enclosure

The enclosure is available in copper-free (0.3%), die-cast aluminum and type 316 stainless steel.




**Built-In Flange for Pipe Mounting** 

The built-in mounting flange allows easy mounting to walls or pipes.



A slot on the back makes it easy to center the unit on a pipe. There are two <sup>3</sup>/<sub>4</sub>" NPT threaded conduit holes for wiring.



**Grounding Screw** A grounding screw is provided on the top of the enclosure.



### SS Tag Attaching Loop

The enclosure is also equipped with a loop at the top to easily attach a PDA-SSTAG stainless steel tag.




**Tamper-Proof Capability** 


The instrument can be made tamper-proof by inserting a wire through the built-in loop on the base of the enclosure and a hole in the lid of the enclosure and securing this wire with a lead seal.

### **Pump Alternation**

The PD6907 can be used as a pump controller to alternate two pumps and indicate high and low alarm conditions. The pumps can be programmed to alternate on level and runtime and the display can be programmed to turn red and flash a message on alarm conditions. The meter can display the pump runtimes and the number of times they have cycled.

See the *Pump Control with* Alternation & Alarm Example on page *48* for full details.





With the Pump Alternation feature activated, the next time the level reaches 30 feet, relay #1 transfers and starts the backup pump. <sup>1</sup> lights up to show relay 1 is energized.



### Easy Wiring & Service

The PD6907 has been designed for easy wiring and servicing. All connections are made to removable screw terminal blocks. There are no exposed printed circuit boards.

### Input Signal Conditioning


The *Function* menu is used to select the input signal conditioner applied to the input: linear or round horizontal tank volume calculation. Multi-point linearization is part of the linear function selection.

Meters are set up at the factory for linear function with 2-point linearization. The linear function provides a display that is linear with respect to the input signal.

#### **Multi-Point Linearization**

Up to 32 linearization points can be selected for PV1 and PV2 under the linear function. Multi-point linearization can be used to linearize the input so the meter can display volume from non-linear tanks or to convert level to flow using weirs and flumes with complex equations to convert level to flow using weirs and flumes with complex equations.

If the dual-scale level feature has been selected, the menus for PV1 & PV2 are enabled.



This function automatically calculates the volume in a round horizontal tank with flat ends and allows that reading to be displayed on the bottom display. This results in a meter that displays the height of the tank in convenient to read feet and inches on the top display and volume on the lower display. The user only needs to enter the diameter and length of the tank and the meter takes care of the rest.

### Round Horizontal Tank Linearization

# **Ordering Information**

### **Hazardous Area Instruments**

ProtEX+ PD6907 • Feet & Inches – Aluminum Enclosure	
Model	Description
PD6907-HA-AL-LNN	Loop-Powered Explosion-Proof & Intrinsically Safe Feet & Inches Meter, No Options
PD6907-HA-AL-L2N	Loop-Powered Explosion-Proof & Intrinsically Safe Feet & Inches Meter, Two Solid-State Relays
PD6907-HA-AL-L3N	Loop-Powered Explosion-Proof & Intrinsically Safe Feet & Inches Meter, 4-20 mA Analog Output
PD6907-HA-AL-L5N	Loop-Powered Explosion-Proof & Intrinsically Safe Feet & Inches Meter, Two Solid-State Relays & 4-20 mA Analog Output

ProtEX+ PD6907 • Feet & Inches – Stainless Steel Enclosure	
Model	Description
PD6907-HA-SS-LNN	Loop-Powered Explosion-Proof & Intrinsically Safe Feet & Inches Meter, No Options
PD6907-HA-SS-L2N	Loop-Powered Explosion-Proof & Intrinsically Safe Feet & Inches Meter, Two Solid-State Relays
PD6907-HA-SS-L3N	Loop-Powered Explosion-Proof & Intrinsically Safe Feet & Inches Meter, 4-20 mA Analog Output
PD6907-HA-SS-L5N	Loop-Powered Explosion-Proof & Intrinsically Safe Feet & Inches Meter, Two Solid-State Relays & 4-20 mA Analog Output

#### Notes:

- 1. All models come with bargraph, two open collector outputs, and one digital input standard.
- 2. The meter comes standard with two ¾" NPT conduit holes. To order models with M20 conduit holes instead, add -21 at the end of the part number (e.g. PD6907-HA-AL-LNN-21)

### Accessories

Model	Description
PD659	Signal Isolators, Splitters, and Conditioners
PD9501	Multi-Function Calibrator
PD9502	Low-Cost Signal Generator
PDA6846-SS	Stainless Steel 2" U-Bolt Kit. All Material: Stainless Steel; (1) U-Bolt for 2" Pipe with (2) Washers, (2) Lock Washers, and (2) Nuts
PDAPLUG75	3/4" NPT 316 Stainless Steel Conduit Plug with Approvals
PDAREDUCER-75M- 50F	M-3/4" NPT to F-1/2" NPT Reducer with Approvals
PDAREDUCER-75M- M20F	M-3/4" NPT to F-M20 Reducer with Approvals
PDA-SSTAG	Custom Stainless Steel Tag (see website for convenient ordering form)

### 

 Accessories do not carry hazardous area approvals unless otherwise specified and are thus not suitable for location in hazardous areas.

### PDA6846-SS 2" U-Bolt Kit



The PDA6846-SS stainless steel U-Bolt Kit provides a convenient way to mount the meter to 1.5" or 2" pipes.

### PDA-SSTAG Stainless Steel Tag



The PDA-SSTAG is a laser etched stainless steel tag that can be customized with three lines of text. Each tag comes with a stainless steel wire and lead seal for easy mounting wherever you need.

### **PD9501 Multi-Function Calibrator**



This <u>PD9501</u> Multi-Function Calibrator has a variety of signal measurement and output functions, including voltage, current, thermocouple, and RTD.

### PD9502 Low-Cost Signal Generator



The <u>PD9502</u> is a low-cost, compact, simple to use 4-20 mA or 0-10 VDC signal generator. It can easily be set for 0-20 mA, 4-20 mA, 0-10 V or 2-10 V ranges. Signal adjustment is made with a one-turn knob. A wall plug is provided with the instrument. Optional USB power bank is available.

# **Specifications**

Except where noted all specifications apply to operation at +25°C.

# Display

Disulari	Dual line I CD with healdight
Display	Dual-line LCD with backlight.
	Top: 0.7" (17.8 mm) 5 digits 7-segment,
	FT-IN & fractions
	Bottom: 0.4" (10.2 mm), 8 alphanumeric
	14-segment characters
	Display may be programmed to turn red and
	flash a user-defined message on
	alarm condition.
On-Screen	See CapTouch Buttons and Status Indicators
Indicators	on page 27 for details.
Top Display	-99FT 11IN 15/16 to 999FT 11IN 15/16
Bottom	8 digits (-9,999,999 to 99,999,999; separated
	by commas) or 8 characters
Display	
Destallart	(all capital & most lower-case letters)
Backlight	Powered by 4-20 mA loop
	Intensity varies with signal level
Bargraph	20 segments, numeric percent indication at
	the top of the bargraph
Display	
Assignment	Bottom display can be assigned to PV, dual-
Assignment	scale (PV2), units, tag, timers, max/min
	values, etc. See Configuring the Display
	(∄□TT⊡M) on page 37 for a complete list of
	assignable parameters.
Decimal Point	Up to seven decimal places on bottom
Decimal Point	Up to seven decimal places on bottom display
Decimal Point	
	display Commas to indicate 1000s
Commas	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only
Commas Dual-Scale	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only The input can be displayed in different scales
Commas	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only The input can be displayed in different scales on the top and bottom displays. For instance,
Commas Dual-Scale	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only The input can be displayed in different scales on the top and bottom displays. For instance, the top display could display the input in
Commas Dual-Scale	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only The input can be displayed in different scales on the top and bottom displays. For instance, the top display could display the input in height units and the bottom display could
Commas Dual-Scale Feature	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only The input can be displayed in different scales on the top and bottom displays. For instance, the top display could display the input in height units and the bottom display could show that same input in volume units.
Commas Dual-Scale Feature Alarm	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only The input can be displayed in different scales on the top and bottom displays. For instance, the top display could display the input in height units and the bottom display could show that same input in volume units. Programmable: loop-powered red backlight,
Commas Dual-Scale Feature	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only The input can be displayed in different scales on the top and bottom displays. For instance, the top display could display the input in height units and the bottom display could show that same input in volume units. Programmable: loop-powered red backlight, flashing display, alarm symbol $\bigstar$ , bargraph
Commas Dual-Scale Feature Alarm Indication	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only The input can be displayed in different scales on the top and bottom displays. For instance, the top display could display the input in height units and the bottom display could show that same input in volume units. Programmable: loop-powered red backlight, flashing display, alarm symbol <b>A</b> , bargraph segment flashes on alarm.
Commas Dual-Scale Feature Alarm Indication Custom	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only The input can be displayed in different scales on the top and bottom displays. For instance, the top display could display the input in height units and the bottom display could show that same input in volume units. Programmable: loop-powered red backlight, flashing display, alarm symbol <b>A</b> , bargraph segment flashes on alarm. Programmable for each relay/open collector:
Commas Dual-Scale Feature Alarm Indication Custom Alarm	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only The input can be displayed in different scales on the top and bottom displays. For instance, the top display could display the input in height units and the bottom display could show that same input in volume units. Programmable: loop-powered red backlight, flashing display, alarm symbol ▲, bargraph segment flashes on alarm. Programmable for each relay/open collector: 8 characters maximum; displayed every 10 sec for
Commas Dual-Scale Feature Alarm Indication Custom Alarm Messages	display         Commas to indicate 1000s         (e.g. 88,987,628) on the bottom display only         The input can be displayed in different scales         on the top and bottom displays. For instance,         the top display could display the input in         height units and the bottom display could         show that same input in volume units.         Programmable: loop-powered red backlight,         flashing display, alarm symbol ▲, bargraph         segment flashes on alarm.         Programmable for each relay/open collector:         8 characters maximum; displayed every 10 sec for         1 sec on bottom display. May be turned off.
Commas Dual-Scale Feature Alarm Indication Custom Alarm Messages Display	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only The input can be displayed in different scales on the top and bottom displays. For instance, the top display could display the input in height units and the bottom display could show that same input in volume units. Programmable: loop-powered red backlight, flashing display, alarm symbol ▲, bargraph segment flashes on alarm. Programmable for each relay/open collector: 8 characters maximum; displayed every 10 sec for 1 sec on bottom display. May be tumed off. Ambient > -10°C: 1 Update/Second
Commas Dual-Scale Feature Alarm Indication Custom Alarm Messages	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only The input can be displayed in different scales on the top and bottom displays. For instance, the top display could display the input in height units and the bottom display could show that same input in volume units. Programmable: loop-powered red backlight, flashing display, alarm symbol ▲, bargraph segment flashes on alarm. Programmable for each relay/open collector: 8 characters maximum; displayed every 10 sec for 1 sec on bottom display. May be turned off. Ambient > -10°C: 1 Update/Second Ambient = -20°C: 1 Update/2 Seconds
Commas Dual-Scale Feature Alarm Indication Custom Alarm Messages Display	display         Commas to indicate 1000s         (e.g. 88,987,628) on the bottom display only         The input can be displayed in different scales         on the top and bottom displays. For instance,         the top display could display the input in         height units and the bottom display could         show that same input in volume units.         Programmable: loop-powered red backlight,         flashing display, alarm symbol ▲, bargraph         segment flashes on alarm.         Programmable for each relay/open collector:         8 characters maximum; displayed every 10 sec for         1 sec on bottom display. May be turned off.         Ambient > -10°C: 1 Update/Second         Ambient = -20°C to -40°C the update rate slows
Commas Dual-Scale Feature Alarm Indication Custom Alarm Messages Display	display         Commas to indicate 1000s         (e.g. 88,987,628) on the bottom display only         The input can be displayed in different scales         on the top and bottom displays. For instance,         the top display could display the input in         height units and the bottom display could         show that same input in volume units.         Programmable: loop-powered red backlight,         flashing display, alarm symbol ▲, bargraph         segment flashes on alarm.         Programmable for each relay/open collector:         8 characters maximum; displayed every 10 sec for         1 sec on bottom display. May be turned off.         Ambient > -10°C: 1 Update/Second         Ambient = -20°C to -40°C the update rate slows         down 1 second for every -2°C
Commas Dual-Scale Feature Alarm Indication Custom Alarm Messages Display	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only The input can be displayed in different scales on the top and bottom displays. For instance, the top display could display the input in height units and the bottom display could show that same input in volume units. Programmable: loop-powered red backlight, flashing display, alarm symbol ▲, bargraph segment flashes on alarm. Programmable for each relay/open collector: 8 characters maximum; displayed every 10 sec for 1 sec on bottom display. May be turned off. Ambient > -10°C: 1 Update/Second Ambient = -20°C: 1 Update/2 Seconds From -20°C to -40°C the update rate slows down 1 second for every -2°C (e.g. at -24°C, 1 update/4 seconds).
Commas Dual-Scale Feature Alarm Indication Custom Alarm Messages Display	display         Commas to indicate 1000s         (e.g. 88,987,628) on the bottom display only         The input can be displayed in different scales         on the top and bottom displays. For instance,         the top display could display the input in         height units and the bottom display could         show that same input in volume units.         Programmable: loop-powered red backlight,         flashing display, alarm symbol ▲, bargraph         segment flashes on alarm.         Programmable for each relay/open collector:         8 characters maximum; displayed every 10 sec for         1 sec on bottom display. May be turned off.         Ambient > -10°C: 1 Update/Second         Ambient = -20°C to -40°C the update rate slows         down 1 second for every -2°C
Commas Dual-Scale Feature Alarm Indication Custom Alarm Messages Display	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only The input can be displayed in different scales on the top and bottom displays. For instance, the top display could display the input in height units and the bottom display could show that same input in volume units. Programmable: loop-powered red backlight, flashing display, alarm symbol ▲, bargraph segment flashes on alarm. Programmable for each relay/open collector: 8 characters maximum; displayed every 10 sec for 1 sec on bottom display. May be turned off. Ambient > -10°C: 1 Update/Second Ambient = -20°C: 1 Update/2 Seconds From -20°C to -40°C the update rate slows down 1 second for every -2°C (e.g. at -24°C, 1 update/4 seconds). Below -40°C the display is not readable, but
Commas Dual-Scale Feature Alarm Indication Custom Alarm Messages Display Update Rate	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only The input can be displayed in different scales on the top and bottom displays. For instance, the top display could display the input in height units and the bottom display could show that same input in volume units. Programmable: loop-powered red backlight, flashing display, alarm symbol ▲, bargraph segment flashes on alarm. Programmable for each relay/open collector: 8 characters maximum; displayed every 10 sec for 1 sec on bottom display. May be turned off. Ambient > -10°C: 1 Update/Second Ambient = -20°C: 1 Update/Seconds From -20°C to -40°C the update rate slows down 1 second for every -2°C (e.g. at -24°C, 1 update/4 seconds). Below -40°C the display is not readable, but all the inputs and outputs work correctly.
Commas Dual-Scale Feature Alarm Indication Custom Alarm Messages Display	display Commas to indicate 1000s (e.g. 88,987,628) on the bottom display only The input can be displayed in different scales on the top and bottom displays. For instance, the top display could display the input in height units and the bottom display could show that same input in volume units. Programmable: loop-powered red backlight, flashing display, alarm symbol ▲, bargraph segment flashes on alarm. Programmable for each relay/open collector: 8 characters maximum; displayed every 10 sec for 1 sec on bottom display. May be turned off. Ambient > -10°C: 1 Update/Second Ambient = -20°C: 1 Update/2 Seconds From -20°C to -40°C the update rate slows down 1 second for every -2°C (e.g. at -24°C, 1 update/4 seconds). Below -40°C the display is not readable, but

# General

Programming	Four CapTouch through-glass buttons when
Method	cover is installed. The CapTouch buttons can
	be used with the cover removed.
	Free PC-based USB MeterView XL
For income of all	programming software.
Environmental	Operating temperature range: -40 to 75°C (-40 to 167°F)
	Storage temperature range:
	-55 to 85°C (-67 to 185°F)
	Installation temperature range:
	-55 to 75°C (-67 to 167°F)
	(The display ceases to function, however
	inputs and outputs continue to operate)
	Relative humidity: 0 to 90% non-condensing Printed circuit boards are conformally coated
Noise Filter	Averages the input signal over a period of
	time between 1 and 16 seconds to dampen
	the effects of a noisy signal that causes a
	jumpy display.
Filter Bypass	0.0 to 99.9% of full scale. Input signal
	changes that are greater than the bypass
Recalibration	value are displayed immediately. Recalibration is recommended at least every
Recampration	12 months.
Max / Min	Max / min readings reached by the process
Display	are stored until reset by the user or until
	power to the meter is turned off.
Tare	Tare function zeros out the meter to remove
	the weight of a container.
	Tare function can be assigned to a function
Deserverd	key or the digital input.
Password	Programmable password restricts modification of programmed settings.
Non-Volatile	All programmed settings are stored in non-
Memory	volatile memory for a minimum of ten years if power is lost.
Normal Mode	64 dB at 50/60 Hz
Rejection	
Connections	Removable screw terminal blocks
	Display terminals: accept 16 to 30 AWG wire
	Relay terminals: accept 12 to 26 AWG wire 4-20 mA output: accept 16 to 30 AWG wire
Tightening	Display terminals: 2.5 lb-in (0.28 Nm)
Torque	Relay terminals: 4.5 lb-in (0.5 Nm)
	4-20 mA output terminals: 2.5 lb-in (0.28 Nm)
Overall	5.25" x 5.65" x 4.80"
Dimensions	(133 x 144 x 122 mm)
	(W x H x D)
Weight	Aluminum: 5.1 lbs (2.3 kg)
-	Stainless Steel: 9.4 lbs (4.3 kg)
Weight Warranty	Stainless Steel: 9.4 lbs (4.3 kg) 3 years parts and labor. See Warranty
-	Stainless Steel: 9.4 lbs (4.3 kg) 3 years parts and labor. See Warranty Information and Terms & Conditions on
-	Stainless Steel: 9.4 lbs (4.3 kg) 3 years parts and labor. See Warranty

# Enclosure

-AL Models:
ASTM A413 LM6 die-cast aluminum,
copper-free, enamel coated.
-SS Models:
ASTM A743 CF8M investment-cast
316 stainless steel
Fluoroelastomer
NEMA 4X, IP68 Explosion-Proof
-AL: Blue; -SS: Silver
Borosilicate glass
Two ¾" NPT threaded conduit openings.
M20 conduits are available. See Ordering
Information on page 11 for details.
Sold separately. See Ordering Information on
page 11 for details.
Built-in flange for wall and pipe mounting.
Enclosure lid may be secured with
tamper-proof seal.
Built-in loop for securing stainless steel tag
5.25" x 5.65" x 4.80"
(133 x 144 x 122 mm)
$(W \times H \times D)$
Aluminum: 4.8 lbs (2.18 kg)
Stainless Steel: 9.0 lbs (4.08 kg)

# Input

Input	4-20 mA
Accuracy	±0.02% of span ±1 count,
	Square root and programmable exponent:
	10-100% FS
Voltage Drop	Without backlight: 1.5 V maximum,
	With backlight: 4.7 V maximum
Equivalent	Without backlight: 75 Ω @ 20 mA
Resistance	With backlight: 235 Ω @ 20 mA
Input	Over current protection to 1 A maximum,
Overload	Over voltage protection to 30 VDC max
	(Between mA+ and mA- / BL-)
Temperature	25 PPM/°C from -40 to 75°C ambient
Drift	
Function	PV1: Linear (2-32 points), square root, or
	programmable exponent
	PV2: Linear (2-32 points) or round horizontal
	tank
Low-Height	1/16 to 999 FT 11IN 15/16 or disable. Point
Cutoff	below at which the display always shows zero.
HART	The meter does not interfere with existing
Transparency	HART communications; it displays the
	4-20 mA primary variable and it allows the
	HART communications to pass through
	without interruption. The meter is not affected if
	a HART communicator is connected to the
	loop. The meter does not display secondary
	HART variables.

# Common Open Collector & Relay Specifications

Number	Two open collectors & two relays
High or Low Alarm	User programmable for high or low alarm
Alarm Deadband	0-100% FS, user programmable
Output Assignment	Alarm, Timer, Stopwatch, or Disable
Alarm Output Source	Assign to PV (PV1, PV2) or Digital Input
On & Off Time Delay	0 to 9,999 seconds
Fail-Safe	Independent for each open collector and
Operation	relay. Fail-safe on, the output is on under normal conditions.
	Fail-safe off, the output is on under alarm conditions.
Alarm Operation	Automatic, automatic with manual override, latching (manual reset anytime), latching with reset after cleared (manual reset only after alarm has cleared)
Alarm Indication	Programmable: loop-powered red backlight, flashing display, alarm symbol <b>A</b> , bargraph segment flashes on alarm.
Custom Alarm Messages	Programmable for each relay/open collector: 8 characters maximum; displayed every 10 sec for 1 sec on bottom display. May be turned off.
Alarm Acknowledge	CapTouch ACK button or external digital input resets output and screen indication.
Auto Initialization	When power is applied to the meter, open collectors and relays will reflect the state of the input to the meter.
Timer Output	One-shot or Continuous Off Time Delay: 1 sec to 99:59:59 (hrs:min:sec) On Time: 1 sec to 99:59:59 (hrs:min:sec)
Stopwatch	Output turns on when started and off when stopped.

# **Open Collector Outputs**

Rating	Isolated open collector, sinking NPN 5-30 VDC @ 150 mA maximum
Output Assignment	Pulse, Alarm, Timer, Stopwatch, or Disable
Pulse Output Source	PV (PV1, PV2) or Test Frequency
Pulse Output Factor	0.000001 to 999,999.9
Pulse Width	0.5 ms @ 1 kHz; 500 ms @ 1 Hz; 50% duty cycle
Pulse Output Frequency	1,000 Hz maximum
Quadrature Pulse Output	Available for Output 2 (90° behind Output 1) 500 Hz max
Alarm Output Source	Assign to PV (PV1, PV2) or Digital Input

# **Solid-State Relays**

250 VAC/VDC @ 0.5 A resistive 38 VA; 250 VAC; 0.3 A pilot duty (inductive) 13 VA; 250 VDC; 0.3 A pilot duty (inductive)
Metal oxide varistors across outputs
Pump Alternation, Alarm, Timer, Stopwatch on/off, or Disable
Assign to PV (PV1, PV2) or Digital Input
Relays may be programmed to alternate with each pump cycle with an elapsed time override where the pumps will alternate regardless of level. Pump alternation time can be programmed for 0 to 999:59 (hrs:min)
Meter will keep track of how long each relay (pump) has operated and display this information.
Meter will keep track of how many times the relays (pumps) have cycled and display this information.

# 4-20 mA Transmitter Output

Accuracy	±0.05% FS ±0.001mA
Output Source	PV1, PV2, re-transmit; reverse scaling allowed
Scaling Range	1.00 to 23.0 mA
Disable	High impedance state, less than 1 mA
Calibration	Factory calibrated 4.00 to 20.00 mA
Underrange	1.0 mA, 3.5 mA, or 3.8 mA (If input < 3.5 mA); or Off; user selectable
Overrange	20.5 mA, 20.8 mA, or 23.0 mA (If input > 20.5 mA); or Off; user selectable
Isolation	500 V input-to-output
Temperature Drift	0.5 µA/°C max from -40 to 75°C ambient
External Loop Power Supply	7.0 VDC to 30.0 VDC maximum
Output Loop Resistance	10-750 Ω @ 24 VDC; 10-1100 Ω @ 30 VDC

# **On-Board Digital Input**

Function	Remote acknowledge/reset relays, reset max/min values, etc. See User section of <i>Display Functions &amp; Messages</i> on page 28 for a complete list of capabilities.
Contacts	2.1 VDC on contact. Connect normally open contacts across DI+ and DI-
Logic Levels	Logic High: 2.4 to 30 VDC (max) Logic Low: 0 to 0.9 VDC

# MeterView XL Software

Availability	Free download from <u>www.predig.com</u>		
System Requirements	Microsoft <sup>®</sup> Windows <sup>®</sup> 10 & 11		
Communica- tions	USB 2.0 (Standard USB A to Micro USB B) Cable provided		
Configuration	Configure all parameters on the meter. Configure meters one at a time.		
Configuration Files	Generate with or without meter connected; Save to file for later use.		
USB Power Connection	The meter is powered by the USB connection during programming. There is no need to apply external power. Note: The meter will not be damaged if external power is applied to it during programming.		
	A WARNING		
The motor	should only be connected to a computer while		

•	The meter should only be connected to a computer while
	it is located in a safe area

Compatibility	Programs created for VantageView+ and ProtEX+ can be run on either meter. No
	other program sharing is permissible.



To download the latest MeterView XL programming software and manual, visit predig.com/meterviewxl.

# **Compliance Information**

# **Electromagnetic Compatibility**

EMC Emissions	<ul> <li>CFR 47 FCC Part 15 Subpart B Class A emissions requirements (USA)</li> <li>ICES-003 Information Technology emissions requirements (Canada)</li> <li>AS/NZS CISPR 11 Group 1 Class A ISM emissions requirements (Australia/New Zealand)</li> <li>EN 55011 Group 1 Class A ISM emissions requirements (EU)</li> <li>EN 61000-6-4 Emissions requirements for Heavy Industrial Environments - Generic</li> </ul>
EMC Emissions and Immunity	EN 61326-1 EMC requirements for Electrical equipment for measurement, control, and laboratory use – industrial use

# Hazardous Area Approvals

UL	Explosion-Proof for use in:
	For Class I, Division 1, Groups B, C, D
	Class II, Division 1, Groups E, F, G
	Class III, Division 1; T6
	Class I, Zone 1, AEx db IIC T6 Gb
	Zone 21, AEx tb IIIC T85°C Db
	Tamb = $-55^{\circ}$ C to $75^{\circ}$ C
	UL Type 4X, IP66 / IP68
	UL File Number: E494837
CSA	Explosion-Proof for use in:
	Class I, Division 1, Groups B, C and D
	Dust Ignition-Proof for use in:
	Class II/III, Division 1, Groups E, F and G; T6
	Flame-Proof for use in:
	Zone 1, Ex d IIC T6
	Ta = -55 to 75°C.
	Enclosure: Type 4X & IP66/IP68
	Certificate Number: CSA 11 2325749
ATEX	Intrinsically Safe for use in:
	⟨€x⟩ II 1 G D
	Ex ia IIC T4 Ga
	Ex ia IIIC T200°C Da
	Ta = -55 to 75°C
	Enclosure: Type 4X & IP66/IP68
	Install per Control Drawing DW2636
	(contained within LIM6908-2)
	Certificate Number: CML 18ATEX2089X
	Explosion-Proof for use in:
	€ 1   2 G D
	Ex db IIC T6 Gb
	Ex tb IIIC T85°C Db IP68
	Ta = -55 to 75°C
	Certificate Number: Sira 10ATEX1116X
IECEx	Intrinsically Safe for use in:
	Ex ia IIC T4 Ga
	Ex la IIIC T200°C Da
	Ta = -55 to 75°C
	Enclosure: Type 4X & IP66/IP68
	Install per Control Drawing DW2636
	(contained within LIM6908-2)
	Certificate Number: IECEx CML 18.0050X
	Explosion-Proof for use in:
	Explosion-Proof for use in: Ex db IIC T6 Gb
	Ex tb IIIC T85°C Db IP68
	$Ta = -55 \text{ to } 75^{\circ}\text{C}$
	Certificate Number: IECEx SIR 10.0056X
	Certificate Number, IECEX SIR 10.0056X

#### ATEX/IECEx Specific Conditions of Use

The following conditions relate to safe installation and/or use of the equipment.

- The equipment loop/power port shall be connected to an intrinsically safe barrier with Uo ≥ 5.8V
- The 4-20 mA input port shall be connected to an intrinsically safe barrier with Uo  $\geq 5.1V$
- The PD6907-HA-AL enclosure is manufactured from aluminum. In rare cases, ignition sources due to impact and friction sparks could occur. This shall be considered during installation, particularly if the equipment is installed in a Zone 0 location.
- All cable entries into the equipment shall be via cable glands or conduit which provide a minimum degree of protection of IP54.
- The equipment may not have 500V isolation between the circuit and earth. This shall be taken into account when installing the equipment.
- The equipment label and epoxy coating may generate an ignition-capable level of electrostatic charges under certain extreme conditions. The user should ensure that the equipment is not installed in a location where it may be subjected to external conditions (such as high-pressure steam) which might cause a buildup of electrostatic charges on non-conducting surfaces. Additionally, cleaning of the equipment should be done only with a damp cloth.
- Flameproof joints are not intended to be repaired.
- All entry closure devices shall be suitably certified as "Ex d", "Ex t" and "IP66/68" as applicable. Suitable thread sealing compound (non-setting, noninsulating, non-corrosive, not solvent based, suitable for the ambient rating) must be used at the NPT conduit entries to achieve the IPx8 rating while maintaining the Ex protection concept.

#### Year of Construction

This information is contained within the serial number with the first four digits representing the year and month in the YYMM format.

### For European Community:

The PD69XX Series must be installed in accordance with the ATEX directive 2014/34/EU, the product certificates CML 18ATEX2089X, Sira 10ATEX1116X, IECEx CML 18.0050X, IECEx SIR 10.0056X and the product manual.

#### UL Specific Conditions of Safe Use

- Flameproof joints are not intended to be repaired.
- "WARNING Potential Electrostatic Charging Hazard – See Instructions." Anodized or epoxy coated aluminum models must not be installed in locations where they may be subjected to conditions (such as high-pressure steam) which might cause a build-up of electrostatic charges on non-conductive surfaces. Additionally, cleaning of the equipment should only be done with a damp cloth.
- The equipment has not been evaluated for sealing of process fluids. The final installation shall include suitable sealing of the process fluids.
- The process temperature range shall not exceed the ambient temperature range of the equipment, if attached.

# EU Declaration of Conformity

For shipments to the EU and UK, a Declaration of Conformity was printed and included with the product. For reference, a Declaration of Conformity is also available on our website www.predig.com/docs.

# **Safety Information**

### 

• Read complete instructions prior to installation and operation of the meter.

#### **WARNINGS**

- Hazardous voltages exist within enclosure. Installation and service should be performed only by trained service personnel.
- The internal grounding terminal shall be used for the equipment grounding connection and that the external terminal is for a supplementary bonding connection where local codes or authorities permit or require such connection.
- If this equipment is used in a manner not specified by Precision Digital, the protection provided by the equipment may be impaired.
- Substitution of components may impair hazardous location safety.
- Service requiring replacement of internal components must be performed at the factory. Entire meter assembly (electronic assembly) may be replaced within the field with a unit supplied from the factory labeled "Field Modification".
- Control room equipment must not use or generate more than 250 VRMS or VDC.
- Hazardous location installation instructions for associated apparatus (barrier) must be followed when installing this equipment.
- For safe installation of an ATEX approved transmitter in series with PD6907 loop-powered feet & inches meters, the hazardous location installation instructions for the transmitter, PD6907 loop-powered feet & inches meter, and associated apparatus (barrier) must be compatible.
- PD6907 loop-powered feet & inches meters do not add capacitance or inductance to the loop under normal or fault conditions.
- Substitution of components may impair hazardous location safety.
- Equipment contains non-metallic materials and therefore special care and consideration should be made to the performance of these materials with respect to chemicals which may be present in a hazardous environment.

# Installation

To access the connectors, remove the enclosure cover and unclip the display module by pulling it from the enclosure. The display module may be disconnected from the options module to facilitate wiring to the options module.

Refer to Control Drawing (DW2636 - Contained within the <u>LIM6908-2</u>) for details related to intrinsically safe field wiring.

#### **WARNING**

Explosion-Proof / Dust Ignition-Proof / Flame-Proof

- Disconnect from supply before opening enclosure.
- Keep cover tight while circuits are live.
- The equipment shall only be connected to a Class 2 power supply.
- All conduit openings must be fitted with suitably certified and dimensioned cable entry devices or stopping plugs.
- Install conduit seals within 18 in. (450 mm) of enclosure.
- Cable must be suitable for 90°C.

# Unpacking

Remove the meter from box. Inspect the packaging and contents for damage. Report damages, if any, to the carrier.

If any part is missing or the meter malfunctions, please contact your supplier or the factory for assistance.

# Mounting

The PD6907 has a slotted mounting flange that may be used for pipe mounting or wall mounting. Alternatively, the unit may be supported by the conduit using the conduit holes provided. Refer to *Figure 1* and *Figure 2*.

#### 

• Do not attempt to loosen or remove flange bolts while the meter is in service.

### Dimensions




Figure 1. Enclosure Dimensions - Front View




Figure 2. Enclosure Dimensions – Side View




Figure 3. Enclosure Dimensions – Top View



### **Cover Jam Screw**

The cover jam screw should be properly installed once the meter has been wired and tested in a safe environment. The cover jam screw is intended to prevent the removal of the meter cover in a flameproof environment without the use of tools. Using a M2 hex wrench, turn the screw clockwise until the screw contacts the enclosure's base. Turn the screw an additional 1/4 to 1/2 turn to secure the cover.



#### 

 Excess torque may damage the threads, screw head, and/or wrench.

# Connections

To access the connectors, remove the enclosure cover and unclip the display module by pulling it from the enclosure. Signal, backlight, open collector, and digital input connections are made to removable connectors on the display module. Relays and 4-20 mA output connections (if installed) are made to removable connectors on the options module mounted in the base of the enclosure. The display module may be disconnected from the options module to facilitate wiring to the options module. Grounding connections are made to the two ground screws provided on the base of the enclosure, one internal and one external.

### 

- Observe all safety regulations. Electrical wiring should be performed in accordance with all agency requirements and applicable national, state, and local codes to prevent damage to the meter and ensure personnel safety.
- Static electricity can damage sensitive components.
- Observe safe handling precautions for static-sensitive components.
- Use proper grounding procedures/codes.
- If the meter is installed in a high voltage environment and a fault or installation error occurs, high voltage may be present on any lead or terminal.

# **Display & Options Modules**

The display module snaps into built-in rails on the enclosure ensuring a secure and perfect fit every time. No tools are needed to install or remove it. The options module is screwed into the base of the enclosure. Both modules completely encase the printed circuit boards.



**Options Board (Left) and Display Module (Right)** 



**Options Board Connected to Display Module** 



**Options Board Mounted on the Bottom of Enclosure** 



**Display Module Mounted on Built-In Rails** 

# **Connectors Labeling**

The following graphics show the locations of the connectors for each available configuration.




Figure 5. Connector Labeling for PD6907-HA-##-L2N

#### PD6907 Ex-Proof & I.S. Loop-Powered Feet & Inches Meter




Figure 6. Connector Labeling for PD6907-HA-##-L3N




Figure 7. Connector Labeling for PD6907-HA-##-L5N

# Wiring Diagrams

### **Intrinsically Safe Wiring**

#### **WARNING**

- PD6907 installation must be performed in accordance with control drawings included in the LIM6908-2, in order to meet agency approval ratings.
- For ATEX certification, barrier and transmitter must be ATEX Certified with Entity Parameters and must be connected per manufacturer's instructions.
- Service requiring replacement of internal components must be performed at the factory.
- Entire meter assembly (electronic assembly) may be replaced in the field with a unit supplied from the factory labeled "Field Modification".

4	-20 m	A Loop Input		Sw	vitch Port		
Ui	=	30 V	Ui	=	30 V		
li	=	175 mA	li	=	175 mA		
Pi	=	1 W	Pi	=	1 W		
Ci	=	0	Ci	=	0		
Li	=	0	Li	=	0		
Ор	en Co	llector Outputs	E	Backli	ght Terminal		
Ui	=	30 V	Ui	=	30 V		
li	=	175 mA	li	=	175 mA		
Pi	=	1 W	Pi	=	1 W		
Ci	=	0	Ci	=	0		
Li	=	0	Li	=	0		
P	ower	Supply Input		m	A Output		
Ui	=	30 V	Ui	=	30 V		
li	=	175 mA	li	=	175 mA		
Pi	=	1 W	Pi	=	1 W		
Ci	=	0	Ci	=	0		
Li	=	0	Li	=	0		
	Rela	y Outputs					
Ui	=	30 V					
li	=	1000 mA					

#### I/O Parameter Table

Pi

Ci

Li

Uo

lo

Po

=

=

= 0

=

=

=

1 W

0.013 uF

11.55 V

0.012 W

1 mA

## **Explosion-Proof Wiring**

### Current Loop (4-20 mA) Connections

Signal connections are made to a three-terminal connector. See Connectors Labeling on page 21. The following figures show a 4-20 mA current loop connected to the meter. Figure 8 shows the connection without the backlight and Figure 9 shows the connection with the backlight (the backlight can be disabled/enabled in the SYSTEM menu, if connected). The meter and the backlight are powered by the 4-20 mA current loop.

There are no switches or jumpers to set up for the input. Setup and programming are performed through the CapTouch buttons or PC-based software.




Figure 8. 4-20 mA Input Connection without Backlight





Figure 9.	4-20 mA	Input Connection	h with Backlight
i igui e J.		mput oonneedo	i with Dackinght

The current input is protected against current overload up to 1 amp. The display may or may not show a fault condition depending on the nature of the overload.

### **Digital Input Connections**

A digital input is standard on the meter. This digital input is connected with a normally open contact across DI+ and DI-, or with an active low signal applied to DI+ and DI-.



**Figure 10. Digital Input Connections** 

#### 4-20 mA Output Connections

Connections for the 4-20 mA transmitter output are made to the connector terminals labeled 4-20 mA Output on *Figure 6*, on page 22. The 4-20 mA output must be powered from an external power supply.




Figure 11. 4-20 mA Output Connections

### **Solid-State Relay Connections**

Relay connections are made to two-terminal connectors, as shown on *Figure 5*, page *21*. Each relay's C terminal is common only to the normally open (NO) contact of the corresponding relay.




Figure 12. Solid-State Relay Connections

### **Open Collector Output Connections**

Open collector output 1 and 2 connections are made to terminals labeled OC1 and OC2 on *Figure 4*, page 21. Connect the alarm or pulse input device as shown below.




Figure 13. Open Collector Output Connections

# **Setup and Programming**

The meter is factory calibrated prior to shipment to display 0.00 to 100.00, which corresponds to the 4-20 mA input. The calibration equipment is traceable to NIST standards.

### **Overview**

There are no jumpers to set; setup and programming is done through the CapTouch buttons or the free MeterView XL PC-based software.

The meter may be powered via the micro-USB connection located on the display module for the purpose of programming only. The backlight will not work while the meter is powered via the USB connection.

# **CapTouch Buttons**

The PD6907 is equipped with four capacitive sensors that operate as through-glass buttons so that it can be programmed and operated without removing the cover (and exposing the electronics) in a hazardous area.



These buttons can be turned off for security by selecting the *Off* setting on the switch located on the side of the display module, close to the Menu button.

To actuate a button, press one finger to the window directly over the marked button area. When the cover is removed, the CapTouch buttons can be used after the meter completes a self-calibrating routine (hand symbol  $\$  flashes). The sensors are disabled when more than one button is pressed, and they will automatically re-enable after a few seconds (hand symbol  $\$  off).

### **CapTouch Buttons Delay**

The CapTouch have two modes of operation: *Normal* and *Delayed*. Use the Delayed mode to prevent accidental trigger of the buttons. In the Delayed mode, the buttons enter into a low sensitivity state (sleep) and they ignore quick button presses after 20 seconds of inactivity. To wake up the buttons, press and hold any button for more than 2 seconds, the buttons respond normally.

### **Turning Off CapTouch Buttons**

The CapTouch buttons can be turned off for security by moving the slide switch located on the display module to the *Off* position.



# CapTouch Button Tips & Troubleshooting

The CapTouch buttons are designed to work under any lighting condition and to protect against false triggering. If the CapTouch buttons are not needed during operation, they can be turned off (slide switch to *Off*).

- To remove cover with power applied (safe area only), or to clean the window, place your hand over the buttons; this will temporarily disable the CapTouch buttons to prevent inadvertent use.
- Keep the glass window clean.
- Tighten the cover securely.
- Use a password to prevent tampering.

### 

• CapTouch buttons will not work if two or more buttons are detected as being pressed simultaneously. Be careful to avoid triggering multiple buttons or reaching across one button location to press another.

### MeterView XL Programming Software



The fastest and easiest way to program the meter is using the free Meterview XL programming software. This software greatly simplifies the programming process and allows the user to save configuration files for later use.

The meter connects to the PC via a provided micro-USB cable and is powered by the USB connection, so no additional power is needed during programming.

eterVi	ew° X		nd save	print send	read about		rect discorr
rain inc	ut / scale	esso display	Jnn. OC cutput	relay output	1-20 mA out	advanced	system
main so	reen						
meter info model number	PD6907						
height readings	edit	reset			PRECISION DIG	TALL	
height	32.98 FT						
volume	19382 GAL						
PV1 percent	49.99%					IN 50%	6
max	49.50 FT				32-1	12 0	
min	16.48 FT					and the second	
meter status				_	193	82 .	6
input signal:	11.998 mA	mA output	11.998 mA				
open collector 1:	Off	relay 1:	Off				
open collector 2:	Off	relay 2:	Off				
password setting:	unlocked	relay info					
PC data logging Stat	inactive Pause	setup	•				

To download the latest MeterView XL programming software and manual, visit predig.com/meterviewxl.

#### 

• The meter should only be connected to a computer while it is located in a safe area.

### 

 Care should be exercised to avoid ground loops when connecting the USB to an active loop (e.g. power supply, transmitter, loop-powered meter, etc.). It is recommended to connect the (mA+) terminal of the meter to the (-) terminal of a twowire transmitter and the (mA-) to the (+) of the next device in the loop or to the (-) terminal of the power supply.

# CapTouch Buttons and Status Indicators



### **Buttons**

Dattonio	
Button	Description
MENU	Menu
<b>F</b> 1	Right Arrow/F1
<b>F</b> 2	Up Arrow/F2
<b>↓</b> ) <b>F3</b>	Enter/F3

- 1. Press the *Menu* button to enter or exit the Programming Mode at any time.
- Press or hold the *Right-Arrow* button to scroll forward through the menus, select digits during numeric programming, select characters during text programming, or decrement the value of a digit or character selected with the *Up-Arrow* button.
- 3. Press and hold the *Right-Arrow* button to zero or clear digits/characters while in data-entry mode.
- 4. Press or hold the **Up-Arrow** button to scroll backwards through the menus or to increment the value of a digit or character.
- 5. Press the *Enter* button to access a menu or to accept a setting or programmed digit/character value.



### Indicators

Indicator	State	Description
₩	Steady	Process trend arrows
	Flashing	Alarm Indicator
A	Steady	Password protected
<b>R1</b>	Steady	Solid-state relay 1
<b>R2</b>	Steady	Solid-state relay 2
Ð	Flashing	CapTouch buttons self-calibrating (wait)
<b>81</b> %	Dynamic	Bargraph percentage value reading
	Steady	PV bargraph
	Flashing	Alarm condition: Bargraph segment flashes on alarm
FT	Steady	Feet value
IN	Steady	Inches value
8	Steady	8 <sup>th</sup> of an inch value
15	Steady	16 <sup>th</sup> of an inch value

### 

 Avoid touching more than one button at a time, otherwise the buttons become unresponsive and enter into a self-calibrating routine. This is indicated by the flashing hand symbol <sup>(b)</sup>.

# **Display Functions & Messages**

The meter displays various functions and messages during setup, programming, and operation. The following table shows the main menu functions and messages in the order they appear in the menu.

Display Functions & Messages	
Parameter	Action/Setting Description
INPUT (PV   and PV 2)	Program the meter 4-20 mA input (two menus, Pt/ 1 and Pt/2, are available if in dual-scale mode; see Pt/2 under advanced features menu)
UNITS	Set the scaling units. PV/PV1: The meter can be scaled in any height units but will always be displayed in feet and inches. The value will automatically be converted to feet and inches. PV2: See Available Unit Classes
INCH	and Units on page 34 Inches
FEET	Feet
FT-IN	Feet & Inches
	Yards
EM	Centimeters
M	Meters
INPUT I	Program input 1 value
DISP (	Program display 1 value
INPUT 2	Program input 2 value (up to 32 points)
DISP 2	Program display 2 value (up to 32 points)
5A/E7	Press Enter to save programmed units, input, and display values. Press Menu to cancel.
OUTPUT	Program the meter's available outputs
OPEN COLLECTR	Program the meter's open collector outputs
OUTPUT I	Open collector 1 setup
OUTPUT2	Open collector 2 setup
DISABLE	Disable the open collector
PULSE	Program the open collector for pulse output
ALARM	Program the open collector for alarm output
TIMER	Program the open collector as a timer
<b>STPWATCH</b>	Program the open collector to turn on while the stopwatch is running
MESSAGE	Select ON to display a message when open collector is on
RELAY	Program the meter's relay outputs
OUTPUT I	Relay 1 setup
OUTPUT2	Relay 2 setup

Display Functions & Messages	
Parameter	Action/Setting Description
DISABLE	Disable the relay
ALARM	Program relay for alarm functionality
PUMPETRL	Program relay for pump control application
TIMER	Program relay as a timer
STPWATCH	Program relay to turn on while the stopwatch is running
MESSAGE	Select ON to display a message when relay is on
RELAY INFO	View relay runtime and cycle count
4-20 MA	Program the meter's 4-20 mA output
PV	Program a range to transmit based on the display value
RETRANS	Retransmit the mA input signal
DISABLE	Disable the 4-20 mA output
EONTROL	Program manual or automatic operation for the outputs
DE 1	Open collector 1
530	Open collector 2
RELAY I	Relay 1
RELAY2	Relay 2
4-20 mA	4-20 mA output
RUTO	Set selected output to automatic operation
MANUAL	Manually control selected output operation
	Program the meter's advanced features
PV SETUP (PV 1&PV 2)	Advanced input programming (two menus, Pl/ I and Pl/ 2, are available if in dual-scale mode; see Pl/ 2 under advanced features menu)
SOURCE	Select PV 2 source (dual-scale only; see PV 2 under advanced features menu)
4-20 mA	Source PV 2 from the mA input
PV I	Source PV 2 from PV 1
FUNETN	Select linear or round horizontal tank (PV2 only)
LINEAR	Set meter for linear function and select number of linearization points
RH TANK	Round horizontal tank (dual-scale only; see 만건 under advanced features menu)
SCALECAL	Scale or calibrate the mA input
5CALE PV (lor2)	Scale the input
CAL PV (¦or2)	Calibrate the input
CUIDEE	

Set low-height cutoff

CUTOFF

Display Fu	Display Functions & Messages	
Parameter	Action/Setting Description	
DISABLE	Disable low-height cutoff	
ENABLE	Enable low-height cutoff	
FILTER	Set noise filter value	
IO SEC	1 second	
20 SEC	2 seconds	
40 SEC	4 seconds	
80 SEC	8 seconds	
160 SEC	16 seconds	
OFF	Turn filter off	
3×PA55	Set filter bypass (0.0 to 99.9% FS)	
PRSSWR]	Set a password for the meter	
USER	Assign function keys / digital input	
Fl	Assign F1 function key	
F2	Assign F2 function key	
F3	Assign F3 function key	
DI	Assign digital input	
DISP FN	Set the function key or digital input to display a value	
DISPLAY	Cycle max, min, and PV(s)	
JISP PV	Display the PV	
PET PV	Display the PV's percentage of max (20 mA)	
D UNITS	Display the PV's units	
J TAG	Display the PV's tag	
DISPMIN	Display the PV's minimum value	
DISPMAX	Display the PV's maximum value	
MIN MAX	Display the PV's minimum and maximum value	
] mR IN	Display the current mA input value	
]] mROUT	Display the current mA output value	
MENU FN	Set the function key or digital input to access a menu	
RLYINFO	Go to relay information menu (INFI)	
MANETRL	Go to output control menu (EBNTROL)	
TIMR OE I	Open collector 1 timer	
TIMR DES	Open collector 2 timer	
TIMER RI	Relay 1 timer	
TIMER R2	Relay 2 timer	
TIMERFN	Set the function key or digital input to start or stop a timer	
STRTALL	Start all timers	
STOPALL	Stop all timers	
SSTPALL	Start or stop all timers	
OC I	Start/stop open collector 1 timer	
530	Start/stop open collector 2 timer	
RLYI	Start/stop relay 1 timer	

Display Functions & Messages	
Parameter	Action/Setting Description
RF A 5	Start/stop relay 2 timer
START	Start the selected timer output
STOP	Stop the selected timer output
915915	Start or stop the selected timer output
ALARMEN	Set the function key or digital input to acknowledge an alarm or access set points
AEK	Acknowledge all active alarms
SETPOINT	Access all output set points
SETPTOE I	Access open collector 1 set point
SETPT <u>0</u> C2	Access open collector 2 set point
SETPTR I	Access relay 1 set point
SETPTR2	Access relay 2 set point
SWATCHEn	Set the function key or digital input to activate stopwatch
START	Start the stopwatch
STOP	Pause/Stop the stopwatch
5TR5TP	Start or stop the stopwatch
TAREFN	Set the function key or digital input to tare the display
TARE	Tare the display value
RST TARE	Reset the display value
HOL] FN	Set the function key or digital input to hold an output
HOLIOUT	Hold all outputs while F1-F3 or DI are active (pressed or on)
UNHOL ]	Displayed when hold all outputs key is released
HL IUNHL I	Displayed when hold all outputs key is released
00 1+5	Hold/un-hold open collector outputs
RLY I+2	Hold/un-hold relay outputs
MADUT	Hold/un-hold 4-20 mA output
HOLD	Hold selected output
HL] UNHL]	Hold or un-hold selected output
DISABLE	Disable function key or digital input
RST FN	Set the function key or digital input to reset a value
RESET	Reset min, max, or max/min PV
R MINMAX	Reset max and min PV value
HINT	Display hint text on key press and execute action on next key press
OFF	Turn the hint function off
ON	Turn the hint function on
SYSTEM	Program system settings
ROUTERL	Calibrate the analog output
DEFAULT	Load factory defaults

Display I	Functions & Messages
Parameter	Action/Setting Description
PV 2	Enable the meter to scale a
	second PV based on the same 4-20 mA input
DISABLE	•
ENABLE	Disable dual-scale feature (default)
	Enable dual-scale feature
BACKLITE	Enable/disable display backlight
	Enable the backlight (default)
	Disable the backlight
	Select CapTouch buttons mode
	CapTouch normal (default)
JELAYED	CapTouch delayed
INFO	View meter software version and model; change the identifier tag
SFT	The software ID number
VER	The software version
MODEL	The meter model number
IITAG	The meter identifier tag Press <i>Enter</i> to edit tag
ICAL	Internal calibration used for scaling
DISPLAY	Program the meter's display
UNITS	Change the feet and inches display for PV (PV1) or PV2 units if enabled
FTIN/*	Display feet and inches with automatically reducing denominator up to sixteenths of an inch
FT-IN/ 16	Display feet and inches with sixteenths of an inch
FT-IN/8	Display feet and inches with eighths of an inch
FT-IN/4	Display feet and inches with quarter inches
FT-IN/2	Display feet and inches with half inches
FT-IN	Display only feet and inches
DECPT	Change the decimal point location
Comma	Enable or disable the use of a comma on the bottom display
ENABLE	Enable comma (default)
DISABLE	Disable comma
JARGRAPH	Turn off or change the bargraph
₽V	Set the bargraph to display the percentage of a user-selected range
OFF	Turn off the bargraph
Ρν ΡΕΤ	Set the bargraph to display the PV percentage of full scale
30TTOM	Select what to display on the bottom display
TRG	Display the tag
STPWATCH	Display the stopwatch
TIMR DE I	Display open collector 1 timer

Display Functions & Messages	
Parameter	Action/Setting Description
TIMR DE2	Display open collector 2 timer
TIMER RI	Display relay 1 timer
TIMER R2	Display relay 2 timer
MIN	Display minimum value
MAX	Display maximum value
MIN MAX	Display alternating min and max
OFF	Turn bottom display off
Ρν ΡΕΤ	Display the process variable percentage of full scale
mA IN	Display the current mA input value
mR OUT	Display the current mA output value
UNITS	Display the units
Pl/	Display the process variable
PV+UNIT	Display the process variable and unit alternating
PV+TAG	Display the process variable and tag alternating
TA@+UNIŁ	Display the tag and unit alternating
PV +U+TRG	Display the process variable, unit, and tag alternating
	selection shown above is for a single enabled in the System – PV 2 menu,


scale setup. If PV 2 is enabled in the System – PV 2 menu, the display selections include PV 2. Below is a list of PV 2 display selections.

uispiay selections.	
PV 2	Display the PV 2 process variable
PV 1+PV2	Display both process variables (dual-scale only; see Pl/ 근 under advanced features menu)
PV2+UNIT	Display the PV 2 process variable and unit alternating
PV2+TAG	Display the PV 2 process variable and tag alternating
₽₽2+0+1	Display the PV 2 process variable, unit, and tag alternating
PV2 PCT	Display the PV 2 process variable percentage of full scale

### Main Menu

The main menu consists of all the meter's programmable functions: Input, Output, Advanced, and Display.

- Press *Menu* button to enter *Programming Mode* then press the *Right-Arrow* button to move forward through the menu and the *Up-Arrow* button to move back.
- Press *Menu* at any time to go back one level or press & hold to exit and return to *Run Mode*. Changes made to settings prior to pressing *Enter* are not saved.
- Changes to the settings are saved to memory only after pressing *Enter/F3* to confirm the setting or pressing *Enter/F3* at the SAVE? screen when available.




Note: The navigation returns to the top

### **Setting Numeric Values**

The numeric values are set using the *Right* and *Up-Arrow* buttons.

- 1. Press Right-Arrow to select next digit and Up-Arrow to increment digit value. The selected digit will flash.
- 2. Press and hold **Up-Arrow** to auto-increment the display value. If you have made a mistake or would like to enter a new value, select the left-most digit, and press and hold the **Right-Arrow** button until all digits reset to zero.
- 3. Press the *Enter* button at any time to accept a setting or *Menu* button to exit without saving changes.

Note: the underscore in the graphic below is provided to show which digit would be flashing.




# Scaling the 4-20 mA Input (INPLIT)

It is very important to read the following information before proceeding to program the meter:

- The meter is factory calibrated prior to shipment to display 0.00 to 100.00 FT, which corresponds to the 4-20 mA input. The calibration equipment is traceable to NIST standards.
- A calibrated signal source is not needed to scale the meter.

Enter the *Input* menu to scale the meter to display the 4-20 mA input. The input can accept any signal from 4 to 20 mA.



### **Available Unit Classes and Units**

The process variable (PV) can be scaled in several different height units. No matter the scaling units, the scaled value will be converted to feet & inches for display. The available scaling units for the PV (or PV 1 in dual-scale mode) are:

INEH	Inches
FEET	Feet
FT-IN	Feet & Inches
YARI	Yards
EM	Centimeters
М	Meters

The meter has six available preprogrammed unit classes when programming PV2: *volume, height, temperature, pressure, weight,* and *rate.* These units are only available when the meter is in dual-scale mode and PV 2 is being programmed. PV 1 can only be programmed with height units.

Each unit class has the following available units to choose from:

Volume Units (/ OLUME)	
GAL	Gallons
L	Liters
IGAL	Imperial Gallons
M3	Cubic Meters
BBL	Barrels
BUSH	Bushels
כטץם	Cubic Yards
cuFL	Cubic Feet
cuIn	Cubic Inches
L.33L	Liquid barrels
333L	Beer barrels
HEELL	Hectoliter
AF	Acre-Foot
CUSTOM	Custom Unit

Height Units (HEIGHT)	
INEH	Inches
FEET	Feet
FT-IN	Feet & Inches
YAR]	Yards
EM	Centimeters
М	Meters
CUSTOM	Custom unit

Temperature Units (TEMP)	
of	Degrees Fahrenheit
02	Degrees Celsius
к	Kelvin
obb	Degrees Rankine

Pressure Units (PRESSURE)	
PSI	Pounds per square inch
InH9	Inches of mercury
InH20	Inches of water
PHmm	Millimeters of mercury
K8/EM2	Kilograms per square centimeter
K8/M2	Kilograms per square meter
m 3Ar-	Millibar
3Ar-	Bar
PA	Pascal
hPA	Hectopascal
KPA	Kilopascal
MPA	Megapascal
CUSTOM	Custom unit

Weight Units (WEIGHT)	
9m	Grams
КЭ	Kilograms
ŁonnE	Tonnes (metric)
02	Ounces
Ь	Pounds
Łon	Tons
CUSTOM	Custom unit


Rate Time Bases (TIME)	
/SECON]	Units per second
/MINUTE	Units per minute
/HOUR	Units per hour
/ ]]AY	Units per day

Rate Units (RATE)	
GAL / (T)	Gallons per time unit (T)
L / (T)	Liters per time unit (T)
IGAL/(T)	Imperial gallons per time unit (T)
M3/(T)	Cubic meters per time unit (T)
33L/(T)	Barrels per time unit (T)
3USH/(Т)	Bushels per time unit (T)
נטץ]/(T)	Cubic Yards per time unit (T)
сиFŁ / (Т)	Cubic Feet per time unit (T)
cuIn/(T)	Cubic Inches per time unit (T)
L, 33L/(T)	Liquid barrels per time unit (T)
333L / (T)	Beer barrels per time unit (T)
HEELL/(T)	Hectoliter per time unit (T)
FIF / (T)	Acre-Foot per time unit (T)
CUSTOM/	Custom unit per time unit (T)

### Setting Custom Units ([USTOM)

When the desired unit class or unit of measure within a class for PV2 is not available, a custom unit may be programmed. Select the [USTIM menu (or [USTIM unit within a unit class) to enter a custom unit name.

Text values are set using the *Right* and *Up-Arrow* buttons. Press *Right-Arrow* to select next character and *Up-Arrow* to increment character value. The selected character will flash. Press and hold the *Up* or *Right-Arrow* buttons to auto-increment or decrement the character. Press *Enter* to accept the character.



Notes:

- Press and hold the **Right-Arrow** while no character is being edited to erase all characters to the right of the flashing character
- Press and hold Up or Right-Arrow to auto-increment or decrement a selected character.
- All text values, including tags and alarm messages, are set in a similar fashion.

### **Scaling Example**

The 4-20 mA input can be scaled to the appropriate values for a given application. The 4 mA input (input 1) should have a corresponding display value (display 1) which represents the low end of the process value range being measured by the transmitter. Likewise, the 20 mA input (input 2) should have a display value (display 2) which represents the high end of the process value range.

**For example:** If the meter is used to display the level of a 100 ft tall tank, the transmitter should send a 4 mA signal when the tank is empty and a 20 mA signal when the tank is full. The meter should be programmed to interpret these inputs on a display range of 0-100, so that at 4 mA the meter will display 0 and at 20 mA the meter will display 100.

Processes which require a non-linear scale can be accommodated using multi-point linearization (LINEAR) and round horizontal tank (RH TANK) functions available in the Advanced menu. See *Input Signal Conditioning Functions* (FUNETN), page *52*.

A signal source is not needed to scale the meter; simply program the inputs and corresponding display values.


#### **MPORTANT**

Reverse Scaling

The meter can be scaled so that 4 mA represents the high end of the process value range being measured by the transmitter and 20 mA represents the low end of the process value range.

# Setting the Display Features (IISPLAY)

The meter's display functions may be programmed using the *Display* menu. This menu consists of the following submenus: *Units, Decimal Point, Comma, Bargraph, Top,* and *Bottom.* 



### Changing the Engineering Units (UNITS)


The LINITS menu is used to change how fractional inches are represented. The options are automatically reducing, 1/16, 1/8, 1/4, 1/2 of an inch, or no fractions. The default setting (FT-IN/H) automatically reduces the fraction to the lowest denominator.

### Changing the Decimal Point (IE[PT)

The decimal point may be set with up to seven decimal places or with no decimal point at all.

Pressing the *Right-Arrow* moves the decimal point one place to the right until no decimal point is displayed, and then it moves to the left most position. Pressing the *Up-Arrow* moves the decimal point one place to the left.


If the dual-scale level feature is selected, the decimal point selections for PV2 are enabled.



# Enabling or Disabling Commas on the Bottom Display ([]]MMR)

The bottom display is set to show a comma separating the thousands and millions place by default if a numeric value is being displayed. This feature can be disabled or enabled using the *Comma* menu.

**Note:** This menu is only available if the meter is in dual-scale mode.



# Display Capabilities Optimization (30110M)

### **Display Configuration Examples**


The bottom display can toggle between a tag and units or if dual-scale mode is used, can display the input in a different scale such as volume. The following graphics show typical configurations:

Top Display: Process Variable Bottom Display: Toggling Between Volume and Units



**Note**: To display units as GALLONS, select custom units and enter the desired text.

Top Display: Process Variable Bottom Display: Toggling Between Volume and Tag



# Configuring the Display (IDTTOM)

The bottom display line (IDITEM) can be programmed to display different values. Use the IDITEM menu to make these changes. If PV2 is enabled, additional options are available for displaying the second PV on the bottom display.


The bottom display (30770M) can be programmed to display:

- Tag (default)
- Stopwatch
- Open Collector 1 or 2 Timer
- Relay 1 or 2 Timer
- Minimum Process Value
- Maximum Process Value
- Alternating Min & Max Process Values
- Off (Blank)
- PV's Percentage of Full Scale
- The mA Input
- The mA Output
- Units
- Process Value (PV)
- Process Value 2 (dual-scale only; see PV 2 under advanced features menu)
- Alternating PV and Units
- Alternating PV and Tag
- Alternating Tag and Units
- Alternating PV, Units, and Tag

Bottom Line Display Parameters
STPWATCH TIMR OCZ TIMR RI TIMR R2 MIN MAX MIN MAX OFF PV PCT MA IN MA OUT UNITS
PV PV+UNIT PV+TAG PV+U+TAG TAG


### Programming the Bargraph (]]ARGRAPH)

The meter comes equipped with a bargraph display for applications where a visual representation of the process variable's percentage of full scale is desirable. This feature can be enabled or disabled using the *Bargraph* menu ( $\exists AR \exists RAPH$ ). The value displayed on the bargraph can be the percentage of full scale ( $P_{i'} P \equiv T$ ) or the percentage of a user-programmable range ( $P_{i'}$ ). If the meter is in dual-scale mode, the bargraph can be assigned to display either PV1 or PV2 using this menu.



# Programming the Outputs (DUTPUT)

All models come with two open collectors. Depending on the model purchased, the meter may include two solid-state relays, and one 4-20 mA output. The *Output* menu will only show options for the available outputs. See *Ordering Information* on page *11* for details.



### Open Collector Outputs (OPEN EOLLEETR)

The meter is equipped with two NPN open collector outputs as a standard feature that may be set up for pulse outputs, alarms, timed pulses, or disabled.

Pulse outputs can be set to transmit the PV value (PV1 or PV2 if meter is in dual-scale mode). Output 2 may be used to generate a quadrature output based on the other open collector output. An output test mode is also selectable to generate pulses at a constant programmable frequency.


Alarms are available based on the PV value or the digital input. The alarm status will show on the display even if the output is not wired.

A timer output (TIMER) turns the open collector on and off at the specified time intervals. The timer can be set as single-shot or continuous timer.

The stopwatch output (STPWRTCH) allows the open collector to be manually activated by starting the stopwatch. The stopwatch count can be displayed on the top or bottom display.

The output may be disabled by selecting <code>BISABLE</code>.

The Open Collector Outputs are programmed in the following manner:




### Pulse Output (PULSE)

The pulse outputs may be programmed to generate a scaled frequency based on the PV and a programmable factor. The factor determines the number of pulses per second generated per unit of measure. For example, if the meter display shows 100 gallons and the factor is set to 2, the number of pulses generated per second would be 200. The maximum frequency is 1,000 Hz.

Setting output 2 to quadrature will duplicate the other open collector output, but lag by 90 degrees out of phase. The other output should be programmed as desired for the quadrature output function and must be a pulse (PLILSE) output selection. The quadrature maximum frequency for both outputs is 500 Hz.

The TEST option will output a fixed number of pulses per second based on the FRED value entered.



### Alarm (ALARM)


Alarm outputs may be assigned to the PV or the digital input. When assigned to the PV, the alarm may be set as either a high alarm or a low alarm. Alarm actions (AUTO, AUTOMAN, LATEH, L-ELEAR) determine how and when the alarm should be reset. They operate as follows:

- Automatic (AUTO): Alarm will reset automatically once the alarm condition has cleared.
- Automatic/Manual (AUTOMAN): Alarm will reset automatically once the alarm condition has cleared but can also be reset using the *Enter* (ACK) button (or whichever function key is set to acknowledge) at any time.
- Latching (LATEH): Alarm must be reset manually and can be done so at any time. Press the *Enter* (ACK) button at any time to clear the alarm.
- Latching with Reset after Clear (L-ELERR): Alarm must be reset manually and can only be done so after the alarm condition has cleared. Press the *Enter* (ACK) button after the alarm condition has cleared to reset the alarm.

If the alarm is set to PV, a set and reset point must be programmed. The set point is the display value at which the alarm will turn on and the reset point is the display value at which the alarm will turn off. If the set point is lower than the reset point, the alarm will be a low alarm; if the set point is higher than the reset point, the alarm will be a high alarm. The digital input alarm will trigger whenever the digital input is triggered.

For both the PV and digital input alarms, a delay before the alarm is turned on or off may be set, as well as a fail-safe feature which reverses the on/off operation of the open collectors.

Alarm states will be displayed on the meter even if no open collector output is physically connected. These may include a red LED backlight, flashing PV value (PV alarm only), a programmable alarm message, an alarm indicator **A**, and flashing bargraph segment.



### Flashing Red Alarm (RE])

The last two lines in the preceding menu flow chart show how to program the display to turn red, flash, and display a message when an alarm occurs.



### Timer (TIMER)

The timer output may be set to generate the timed pulse only once (INESHIT) or continuously ([INT).


The timer output produces a constant width pulse at a constant frequency, if set as continuous timer. Program the *Off Delay* (DFF\_DLAY) from 1 second to 99 hours 59 minutes and 59 seconds. This is the time it takes from selecting START to turning on the output and for how long the output is off in continuous mode.

Program the *On Time* (IN TIME) for the active low pulse from 1 second to 99 hours 59 minutes and 59 seconds (pulse width). This is the period of time for which the output will remain on.

Select Start (START) to begin outputting the constant timed pulse.

Select Stop (STOP) to end outputting the constant timed pulse.

Function keys or the digital input may be assigned to start and stop timer functions (see the USER menu in the Advanced Menu).



### Stopwatch (STPWATEH)

The stopwatch function may be used to manually run and control a process for a specific time interval up to 99 hrs., 59 min, and 59 seconds. The stopwatch function may be assigned to any open collector. There are three settings needed to use the function effectively.

- 1. Assign stopwatch to either top or bottom display
- Assign the open collector to control the process (on/off)
- 3. Assign a function key or digital input to start/stop the stopwatch

#### **Application Example**

To maintain consistency of a product, it is necessary to take and test samples at different times throughout the day. The stopwatch function is used to open and close a solenoid valve to know the exact amount of time needed to complete the desired sample. Once this is determined, the timer function can be used to automatically take a sample (batch) based on the time determined using the stopwatch function.

Setup: Assign the following to Stopwatch Function

- Bottom display (see pages 35 & 37 for details how to change the display)
- Relay 1
   (see pages 38 & 44 how to change Open Collector and Solid-State Relay functionality)
- F3: Start/Stop (see pages 58 & 59 for details on how to change the function keys)

#### Procedure

- Press F3 to start the stopwatch; relay 1 turns on and the process starts running.
- Press F3 to stop the stopwatch; relay 1 turns off and the process stops.
- The bottom display indicates the time it took to complete the sample.

### Solid-State Relay Outputs (RELAY)

The meter can be optionally equipped with two solid-state relays that may be set up for alarms, timer, stopwatch, or pump control. Alternatively, they may be disabled.

Alarms are available based on the PV value or the digital input. The alarm status will show on the display even if the output is not wired.

Pump control allows the relay to turn on and off a pump at specified on and off points. This can be done using only one of the relays to control one pump ( $\square N - \square FF$ ) or using both relays in tandem to alternate between two pumps ( $\square L T \in RN$ ).


A timer output (TIMER) turns the relay on and off at the specified time intervals. The timer can be set as single-shot or continuous timer.

The stopwatch output (STPWATEH) allows the relay to be manually activated by starting the stopwatch. The stopwatch count can be displayed on the top or bottom display.

The output may be disabled by selecting **JISA**LE.

### 

• During setup, the relays do not follow the input and they will remain in the state found prior to entering the *Relay* menu.



### Alarm (ALARM)


Alarm outputs may be assigned to the PV or the digital input. When assigned to the PV, the alarm may be set as either a high alarm or a low alarm. Alarm actions (AUTO, AUTOMAN, LATEH, L-ELEAR) determine how and when the alarm should be reset. They operate as follows:

- Automatic (RUTO): Alarm will reset automatically once the alarm condition has cleared.
- Automatic/Manual (AUT MAN): Alarm will reset automatically once the alarm condition has cleared but can also be reset using the *Enter* (ACK) button (or whichever function key is set to acknowledge) at any time.
- Latching (LRT[H): Alarm must be reset manually and can be done so at any time. Press the *Enter* (ACK) button at any time to clear the alarm.
- Latching with Reset after Clear (L--ELEAR): Alarm must be reset manually and can only be done so after the alarm condition has cleared. Press the *Enter* (ACK) button after the alarm condition has cleared to reset the alarm.

If the alarm is set to PV, a set and reset point must be programmed. The set point is the display value at which the alarm will turn on and the reset point is the display value at which the alarm will turn off. If the set point is lower than the reset point, the alarm will be a low alarm; if the set point is higher than the reset point, the alarm will be a high alarm. The digital input alarm will trigger whenever the digital input is triggered.

For both the PV and digital input alarms, a delay before the alarm is turned on or off may be set, as well as a fail-safe feature which reverses the on/off operation of the relays.

Alarm states will be displayed on the meter even if no relay output is physically connected. These may include a red LED backlight, flashing PV value (PV alarm only), a programmable alarm message, an alarm indicator **A**, and flashing bargraph segment.



### Pump Control (PUMP[TRL)


The pump control output is used in situations where the relays are used to control pumps. There are two options available for controlling pumps: on-off ( $\Box N$ - $\Box FF$ ) and pump alternation (ALTERN).

[N--]FF will turn the relay on at a programmed *on* point and off at a programmed *off* point. Setting the *on* point higher than the *off* point will make the output activate on a high PV value; setting the *on* point lower than the *off* point will make the output activate on a low PV value. The relay will reset automatically.

For pump control applications where two similar pumps are used to control the level of a tank or a well, it may be desirable to have the pumps operate alternately. This prevents excessive wear and overheating of one pump over the lack of use of the other pump. Pump alternation uses both relays in tandem to alternate between two similar pumps. The RLTERN menu is only available under Output 1 and will automatically set Output 2 to pump alternation as well. Use the pump *Alternation Time* setting (RLTIME) to control the alternation based on runtime in addition to level cycles.

### On/Off Pump Control (ON-OFF)

When programming a single pump to turn on and off, the *on* and *off* points must be programmed. The relay will activate at the *on* point and deactivate at the *off* point. On and off delays may be programmed to delay the activation or deactivation of the relay by a certain number of seconds after reaching either the *on* point or *off* point.




### Pump Alternation (ALTERN)

Pump alternation sets the two relays to alternate every time the first *on* point  $(\square N \ |)$  is reached. The active relay will turn off once the first *off* point  $(\square FF \ |)$  is reached. If the PV reaches the second *on* point  $(\square N \ |)$ , the other relay will also turn on. The second relay will turn off once the second *off* point  $(\square FF \ |)$  is reached. If the PV reaches the second *on* point  $(\square N \ |)$ , the other relay will also turn on. The second relay will turn off once the second *off* point  $(\square FF \ |)$  is reached.

On and off delays may optionally be programmed for each *on* and *off* point to delay the activation or deactivation of the relays by a certain number of seconds after reaching either the *on* point or *off* point.

For pumps that typically remain on extensively, the alternation time (RLTTIME) parameter sets a period of relay ontime after which the relays should alternate. For example, if the alternation time is set to one hour, pump 1 will turn off after one hour of runtime regardless of the level reading, at which point pump 2 becomes the active pump. Pump 2 will run until one hour has passed, or the tank has reached a desirable level; whichever happens first. By using the proper on/off points, the alternation can be set up so that the first pump on is the first pump off. This is desirable when the two pumps are of similar rating.



### Pump Control with Alternation & Alarm Example


The following is a typical application where the relays and open collectors are used for pump alternation and high and low level alarm.

Pump and	Alarm	On &	Off Po	int Progra	amming
----------	-------	------	--------	------------	--------


Relay	On Point	Off Point	Function	OC	On
1	35 feet	10 feet	Controls backup pump	1	3
2	30 feet	10 feet	Controls main pump	2	

OCOn PointOff PointFunction135 feet34 feetTrips high alarm25 feet6 feetTrips low alarm


The following graphics provide a visual representation of a typical pump alternation application:



3



With the Pump Alternation feature activated, the next time the level reaches 30 feet, relay #1 transfers and starts the backup pump. If lights up to show relay 1 is energized.



If the backup pump is not able to keep up, and the level reaches 35 feet, relay #2 transfers and starts the main pump as well. Open collector #1 trips the High Level Alarm, the display turns red and flashes "Hi Level" message, and indicates an alarm condition. The High Level Alarm resets at 34 feet.

▶ **F**1 **F**2 **F**3

1

00

Relay

Backup

00

Lo Alarm

4-20 mA

Signal

Level Transmitter

> ON 35FT OFF 34FT

> > Once the level has dropped below the reset points, both relays will turn off. If the Main Pump fails to turn off, open collector #2 trips the Low Level Alarm at 5 feet to warn against the pump running dry. The Low Level Alarm resets at 6 feet.


### Timer (TIMER)

The timer output may be set to generate the timed pulse only once (DNESHOT) or continuously (CONT). The timer output produces a constant width pulse at a constant frequency, if set as continuous timer.

Program the Off Delay (DFF\_JLAY) from 1 second to 99 hours 59 minutes and 59 seconds. This is the time it takes from selecting START to turning on the output and for how long the output is off in continuous mode.

Program the *On Time* (INTIME) for the active low pulse from 1 second to 99 hours 59 minutes and 59 seconds (pulse width). This is the period of time for which the output will remain on.

Select *Start* (START) to begin outputting the constant timed pulse. Select *Stop* (START) to end outputting the constant timed pulse. Function keys or the digital input may be assigned to start and stop timer functions (see the USER menu in *Advanced*).



### Stopwatch (STPWATEH)

The stopwatch function may be used to manually run and control a process for a specific time interval up to 99 hrs., 59 min, and 59 seconds. The stopwatch function may be assigned to any relay. There are three settings needed to use the function effectively.

- 1. Assign stopwatch to either top or bottom display
- 2. Assign the relay to control the process (on/off)
- 3. Assign a function key or digital input to start/stop the stopwatch

#### **Application Example**

To maintain consistency of a product, it is necessary to take and test samples at different times throughout the day. The stopwatch function is used to open and close a solenoid valve to know the exact amount of time needed to complete the desired sample. Once this is determined, the timer function can be used to automatically take a sample (batch) based on the time determined using the stopwatch function.

Setup: Assign the following to Stopwatch Function


- Bottom display
  - (see pages 35 & 37 for details how to change the display)
- Relay 1 (see pages 38 & 44 how to change Open Collector and Solid-State Relay functionality)
- F3: Start/Stop (see pages 58 & 59 for details on how to change the function keys)

#### Procedure

- Press F3 to start the stopwatch; relay 1 turns on and the process starts running.
- Press F3 to stop the stopwatch; relay 1 turns off and the process stops.
- The bottom display indicates the time it took to complete the sample.

### Runtime & Cycle Count (INFI)

The relay information menu shows runtime and cycle count for each relay. These values may be cleared at any time by selecting the *Clear* option (<code>CLEAR?</code>).




### Isolated 4-20 mA Output (H--20 mA)

The 4-20 mA menu is used to scale the isolated 4-20 mA output based on display values. This menu is not present on models without a 4-20 mA output option.

The 4-20 mA analog output can be scaled to provide a 4-20 mA signal for any PV display range or to simply retransmit the 4-20 mA input. The output may be disabled (JISALE), and will only output the minimum signal.

Overrange and underrange values determine what mA signal the meter will output if the mA input is underrange (<3.5 mA) or overrange (>20.5 mA). This value may be set to 1 mA, 3.5 mA, 3.8 mA, 20.5 mA, 20.8 mA, 23 mA, or disabled.

No equipment is needed to scale the analog output; simply program two display values and corresponding mA output signals.



### Process Variable (PV)

To scale the analog output, enter display value 1 and a corresponding analog output value for this display, and enter display value 2 and a corresponding analog output value for this display value. This will provide a scaled linear analog output.

### Retransmit (RETRANS)

This option will retransmit the 4-20 mA analog input without the need to scale the output.

### Output Manual Control ([[NTR]]])


The *Control* menu is used to control the open collector outputs, 4-20 mA analog output, and the relays manually, ignoring the input. Each open collector, relay, and analog output can be programmed independently for manual control. Selecting automatic control sets all relays and analog output for automatic operation.

After selecting manual control for a specific output, you can set the output value. To change the output value, return to the Control menu, select the output to control, select manual control, and enter a new value.




# Advanced Features Menu (AIV ANCE)

To simplify the setup process, functions not needed for most applications are located in the Advanced Features menu. The options under advanced features include advanced PV setup, cutoff, filter, password, function key programming, and system settings.



### Advanced Process Variable Setup (RIV PV)

The Advanced PV Setup menu contains options to apply input signal conditioning functions to the input and to scale/calibrate the input signal.




### Input Signal Conditioning Functions (FUNETN)

The *Function* menu is used to select the input signal conditioner applied to the input: linear, square root, programmable exponent, or round horizontal tank volume calculation. Multi-point linearization is part of the linear function selection.


Meters are set up at the factory for linear function with 2-point linearization. The linear function provides a display that is linear with respect to the input signal.

To use the PV 2 functions, PV 2 must be enabled in the System - PV 2 menu.



### Using MeterView XL

MeterView XL makes programming the input signal conditioning functions quick and easy. Go to the input/scale menu and select the desired function from the drop down menu in the "scale input" section.




### Multi-Point Linearization (LINEAR)

Up to 32 linearization points can be selected for PV1 and PV2 under the LINERR function. Multi-point linearization can be used to linearize the input so the meter can display volume from non-linear tanks or to convert level to flow using weirs and flumes with complex equations. These points are established via direct entry (GERLE) or with a live calibration signal source (ERL).

If the dual-scale level feature has been selected, the menus for PV1 & PV2 are enabled.




MeterView XL showing the linear points setup feature. Up to 32 points can be selected for PV1 and PV2.



### Round Horizontal Tank Linearization (RH TANK)


This function automatically calculates the volume in a round horizontal tank with flat ends. It is only available for PV2 while the meter is in dual-scale mode.

Select units (feet, inches, or cm) for the tank dimensions. Enter the diameter and the length in feet & inches or cm and the results will be calculated automatically in US gallons or liters. The unit of measure for the volume can be changed using the display menu. See *Changing the Engineering Units* (UNIT5) on page 36 and *Available Unit Classes and Units* on page 34 for a list of available volume units. There is no need to enter scaling values.





MeterView XL Round Horizontal Tank Function Automatically Calculates the Volume Once the Diameter and the Length of the Tank are Entered.



PD6907 Displaying Height in Feet and Volume in Gallons in a Round Horizontal Tank Using the Round Horizontal Tank Linearization Feature.

### Advanced Scaling and Calibration (SEALEEAL)

This menu offers options to scale or calibrate the meter.

### Scaling the Input (SEALE)

The scale menu in the *Advanced* menu is the same as the scale menu in the *Input* menu. See *Scaling the 4-20 mA Input*(INPUT) on page 33 for details about scaling the meter.


### Calibrating the Input (CAL)

To scale the meter without a signal source, refer to Scaling the 4-20 mA Input (INPUT) on page 33.

The meter can be calibrated to display the process in engineering units by applying the appropriate input signal and following the calibration procedure. The [AL menu can be used either with a calibrated current source or with a live signal coming from a 4-20 mA transmitter connected to the process being measured.

During calibration, the mA input value will be displayed as INP | and INP 2. Adjust the input source until the desired mA value is shown.

The use of a calibrated signal source is required.



Follow these steps to calibrate the input:

- 1. After accessing the SEALEEAL menu, press the *Right-Arrow* button to scroll to the *Calibration* menu (EAL PI/) and press *Enter*.
- 2. Select the appropriate units for the desired process variable, then press *Enter*. For information on units, see *Available Unit Classes and Units* on page 34.
- 3. The meter displays INP 1. Apply a known signal and press *Enter*. The display will flash while accepting the signal.
- 4. After the signal is accepted, the meter displays **1**5P **1**. Enter a corresponding display value for the input signal, and press *Enter* to accept.
- 5. The meter displays INP 2. Apply a known signal and press *Enter*. The display will flash while accepting the signal.
- 6. After the signal is accepted, the meter displays ISP 2. Enter a corresponding display value for the input signal and press *Enter* to accept.
- 7. After completing calibration, the SAVE? display will need to be acknowledged using the *Enter* key before calibration will take effect.

Note: The SAVE? prompt is not displayed if no changes have been made to the scaling.

### Low-Height Cutoff ([UTDFF)

The low-height cutoff feature allows the meter to be programmed so that the often-unsteady output from a differential pressure transmitter at low flow rates always displays zero on the meter. The cutoff value may be programmed from 0.1 to 99999. The meter will display zero below the cutoff value. The cutoff can be disabled to display negative values.

### Noise Filter (FILTER)

The noise filter is available for unusually noisy signals that cause an unstable process variable display. The noise filter averages the input signal over a certain period of time. The filter level determines the length of time over which the signal is averaged. The filter level can be set between 1 and 16 seconds or turned off. The higher the filter level, the longer the averaging time and so the longer it takes the display to settle to its final value. Setting the filter level to off disables the filter function.


### Noise Filter Bypass (]YPR5)

The noise filter bypass changes the behavior of the meter so that small variations in the signal are filtered out but large abrupt changes in the input signal are displayed immediately. The bypass value determines the minimum amount of signal change to be displayed immediately. All signal changes smaller than the bypass value are filtered or averaged by the meter. The noise filter bypass may be set between 0.1 and 99.9% of full scale.

### Enabling Password Protection (PASSWR])

The *Password* menu is used for programming security to prevent unauthorized changes to the programmed parameter settings.

To set a password, enter the *Password* menu and program a five-digit password. When a password has been enabled, the lock icon **û** will display in the upper-left side of the display. For instructions on how to program numeric values see *Setting Numeric Values* on page *32*.



### Making Changes to a Password Protected Meter

If the meter is password protected, the meter will display the message LILKE when the *Menu* button is pressed. Press the *Enter* button while the message is being displayed and enter the correct password to gain access to the menu. After exiting *Programming Mode*, the meter returns to its password protected condition.


### **Disabling Password Protection**

To disable password protection, access the *Password* menu and clear the entered password either by pressing and holding the *Right Arrow* button until all digits reset to zero or manually changing all the digits to zero. When the *Enter* button is pressed, the meter will display UNLOCK and will no longer require a password to access *Programming Mode*.

**Note:** If the meter is password protected and the password has been forgotten, the password may be overridden using the master password: **50865** 

### Programmable Function Keys User Menu (USER)

The *User* menu allows the user to assign the CapTouch buttons function keys F1, F2, and F3, and the digital input (located on the input signal connector) to access some of the menus or to activate certain functions immediately (e.g. reset max & min, hold relay states, etc.). This allows the meter to be greatly customized for use in specialized applications.



### Function Keys & Digital Input Available Settings

Refer to the following table for descriptions of each available function key or digital input setting.

Display	Description	
DISP FN	Set the function key or digital input to display a value	
DISPLAY	Cycle max, min, and PV(s)	
DISP PV	Display the PV	
ΡΕΤ Ρν	Display the PV's percentage of max (20 mA)	
D UNITS	Display the PV's units	
] TAG	Display the PV's tag	
DISPMIN	Display the PV's minimum	
DISPMAX	Display the PV's maximum	
MIN MAX	Display the PV's minimum and maximum value	
] mR IN	Display the mA input value	
] mROU⊺	Display the mA output value	
MENU FN	Set the function key or digital input to access a menu	
RLYINFO	Go to relay information menu (INFI)	
MANETAL	Go to output control menu (CONTROL)	
TIMR OC I	Open collector 1 timer	
TIMR OC2	Open collector 2 timer	
TIMER RI	Relay 1 timer	
TIMER R2	Relay 2 timer	
TIMERFN	Set the function key or digital input to start or stop a timer	
STRTALL	Start all timers	
STOPALL	Stop all timers	
SSTPALL	Start or stop all timers	
OC 1	Start/stop open collector 1 timer	
530	Start/stop open collector 2 timer	
RLY I	Start/stop relay 1 timer	
RL Y 2	Start/stop relay 2 timer	
START	Start the selected timer output	
STOP	Stop the selected timer output	
516216	Start or stop the selected timer output	
ALARMEN	Set the function key or digital input to acknowledge an alarm	
AEK	Acknowledge all active alarms	
SETPOINT	Set all output set point	
SETPTOE I	Set open collector 1 set point	
SETPTOE2	Set open collector 2 set point	
SETPTR I	Set relay 1 set point	
SETPTRO	Set relay 2 set point	
SWATCHEN	Set the function key or digital input to activate stopwatch	

Display	Description
START	Start the stopwatch
STOP	Pause/Stop the stopwatch
518216	Start or stop the stopwatch
TAREFN	Set the function key or digital input to tare the display value
TARE	Tare the display value
RST TARE	Reset the display value
HOL] FN	Set the function key or digital input to hold an output
HOLIOUT	Hold all outputs
HL DUNHL D	Hold or un-hold all outputs
OC I+2	Hold/un-hold open collector outputs
RLY 1+2	Hold/un-hold relay outputs
MACUT	Hold/un-hold 4-20 mA output
HOLD	Hold selected output
HL DUNHL D	Hold or un-hold selected output
DISABLE	Disable the function key or digital input
RST FN	Set the function key or digital input to reset a value
RESET	Reset min, max, or max/min PV value
R MINMAX	Reset max and min PV value

# Enabling the Function Key Hint Feature (HINT)

Enabling the function key hint feature will cause a hint message to be displayed when pressing the F1, F2, or F3 function keys. This text gives a brief description of what the button is programmed to do. Pressing that function key a second time will execute that action.

The hint feature does not affect the digital input (DI) which is intended for immediate execution.

### Tare (TARE)

The tare function zero's out the display. In the case of scale weight, tare is used to eliminate container weight and provide net weight readings. There are two tare functions; Tare and Reset Tare. When the tare function is used, the display reading is offset by the displayed amount to make the displayed value zero. Reset tare removes the display offset of the net value, and the gross and net values become the same until a new capture tare is entered.


Program a function key or the digital input for the tare and reset tare.



### Changing System Settings (5Y5TEM)

The System menu contains the following menus: Analog Output Calibration, Restore Factory Defaults, Dual-Scale (PV2), Backlight, CapTouch Buttons Operation Mode, Information, and Internal Calibration.

**Note:** The Analog Output Calibration menu is available only if the option is installed.




# Analog Output Calibration (ROUTERL)

To perform the analog output calibration, it is recommended to use a milliamp meter with a resolution of at least 0.1  $\mu$ A to measure the output current. The values saved internally during this procedure are used for scaling the 4-20 mA output in the *Setup* menu.

### 4-20 mA Output Calibration Procedure

- 1. Go to the Advanced Features menu and navigate to the SYSTEM menu and press Enter. Navigate to ROUTERL and press Enter.
- 2. The display will show 4 mA. The ProtEX+ mA output should now be close to 4 mA. Enter the actual value read by the digital mA meter on the bottom display and press Enter.
- The display will show 20 mA. The ProtEX+ mA output should now be close to 20 mA. Enter the actual value read by the digital mA meter on the bottom display and press Enter.
- 4. The ProtEX+ will now calculate the calibration factors and store them.
- 5. Press Menu to exit.

# Enabling the Dual-Scale Feature (PV2)



#### Dual-Scale Mode

**Top Display:** Toggling Between Process Variable and Units **Bottom Display:** Toggling Between Process Variable (in different scale) and Different Units

For some level applications, such as displaying the height and volume of a tank, a second PV can be enabled which can be scaled to display a different value based on the same 4-20 mA input. This is accomplished by enabling the dual-scale feature (PV 2).

When the dual-scale feature is enabled, additional menus will be displayed to allow for the programming of the second PV. The input menu will display PV1 and PV2 for scaling and the display menu will allow both PVs to be displayed on either top or bottom display, for example. See *Display Functions & Messages* on page *28* for additional information on where additional dual-scale specific menus will appear.

PV2 must be enabled to use the Round Horizontal Tank feature. See *Round Horizontal Tank Linearization* (RH TANK) on page 55.

For instructions on how to enable PV2 see *Changing System Settings* (5Y5TEM) on page *60.* 

### Enabling or Disabling the Backlight (]]A[KLITE)

The backlight may be enabled or disabled using the System - Backlight menu. The backlight is enabled by default, but the input must be wired appropriately for the backlight to function. See *Wiring Diagrams* on page 23.

### CapTouch Buttons Operation Mode (CAPTOUCH)

CapTouch buttons have two modes of operation: Normal and Delayed. Delayed mode prevents accidental trigger of the buttons. In the Delayed mode, the buttons enter into a low sensitivity state (sleep) and they ignore quick button presses after 20 seconds of inactivity. To wake up the buttons, press and hold any button for more than 2 seconds, the buttons respond normally.

# Viewing System Information (INFO)

System information, such as software (firmware) number and version, model number, and system tag, may be viewed in the INFT menu. Press the *Right Arrow* button to cycle through all available meter information. Press **Menu** to go back to the previous menu.

### Calibrating the Internal mA Reference (ICAL)

The meter is factory calibrated prior to shipment to display 0.00 to 100.00, which corresponds to the 4-20 mA input. The calibration equipment is traceable to NIST standards.


The use of calibrated signal sources is necessary to calibrate the internal source of the meter. The meter's internal source is what allows the user to scale the meter without applying a signal.

Check calibration of the meter at least every 12 months.

**Note:** Allow the meter to warm up for at least 15 minutes before performing the internal source calibration procedure.

The *Internal Calibration* menu is part of the *Advanced* menu. Internal Calibration is performed as follows:

- 1. Press the *Menu* button to enter *Programming Mode*.
- 2. Press the *Up-Arrow* button twice and press *Enter* to access the *Advanced* menu.
- 3. Press the *Up-Arrow* button and press *Enter* to access the *System* menu.
- 4. Press the *Up-Arrow* button and press *Enter* to access the *ICAL* menu.
- The meter displays *low* input current message (4000 mR). Apply a 4 mA signal and press *Enter*. The display flashes for a moment while the meter is accepting the low input signal.
- After the display stops flashing, the display moves to the *high* input calibration (2000 mR). Apply the high input signal and press *Enter*. The display will flash again while the meter is accepting the high input signal.



# **Meter Operation**

The meter is equipped with four CapTouch throughglass buttons. These buttons allow meter operation without removing the cover and exposing the electronics in a hazardous area.

Three CapTouch buttons labeled F1, F2, and F3 can be programmed as function keys to perform a variety of meter functions simply by pressing on the glass over the button. These include operation of the tare function, resetting the tare, resetting the meter's relays or open collectors, starting and stopping timers, and displaying max/min values. See *Function Keys & Digital Input Available Settings* on page 59 for a complete list of settings available.

A digital input is available on the meter and it may function in a similar fashion as the function keys to allow remote operation of a single task.

The max & min readings (peak & valley) reached by the process can be displayed either continuously by assigning it to a display line in the *Display* menu, or momentarily by pressing the F1 key (default) or assign it to any of the other function key or the digital input.

Pressing the F1 key cycles through various display values (e.g. max, min); press the Enter key to lock the display in the current process value and press the Enter key again to unlock the display.

The relay information menu shows runtime and cycle count for each relay.

Change the PV2 display units within the selected unit class at any time without the need to re-scale the meter. Select the desired units via the UNITS menu in the DISPLAY menu, and the meter automatically converts the display values to the new unit of measure.

# **CapTouch Buttons Operation**

Button	Description (Default Settings)
MENU	Press to enter or exit <i>Programming</i> <i>Mode</i> , view settings, or exit max/min readings
<b>F</b> 1	Press to display max/min readings.
F2	Press to reset max/min readings.
<b>←</b> ⊃ <b>F3</b>	Press to acknowledge all manually resettable relays or open collectors.
	Press to lock/unlock the display value after pressing the F1 key.

# CapTouch Buttons

The PD6907 is equipped with four capacitive sensors that operate as through-glass buttons so that it can be programmed and operated without removing the cover (and exposing the electronics) in a hazardous area.



These buttons can be turned off for security by selecting the *Off* setting on the switch located on the side of the display module, close to the Menu button.

To actuate a button, press one finger to the window directly over the marked button area. When the cover is removed, the CapTouch buttons can be used after the meter completes a self-calibrating routine (hand symbol & flashes). The sensors are disabled when more than one button is pressed, and they will automatically re-enable after a few seconds (hand symbol & off).

### CapTouch Button Tips & Troubleshooting

The CapTouch buttons are designed to work under any lighting condition and to protect against false triggering. If the CapTouch buttons are not needed during operation, they can be turned off (slide switch to *Off*).

- To remove cover with power applied (safe area only), or to clean the window, place your hand over the buttons; this will temporarily disable the CapTouch buttons to prevent inadvertent use.
- Keep the glass window clean.
- Tighten the cover securely.
- Use a password to prevent tampering.

### 

• CapTouch buttons will not work if two or more buttons are detected as being pressed simultaneously. Be careful to avoid triggering multiple buttons or reaching across one button location to press another.

# **Function Keys Operation**

During operation, the programmable function keys operate according to the way they have been programmed in the *Advanced Features – User* menu. The table under *CapTouch Buttons Operation* on page 62 shows the factory default settings for F1, F2, and F3.

A hint message may be enabled to provide a description of what each function key does prior to executing their assigned function. See *Enabling the Function Key Hint Feature* (HINT) on page 59.

# **Digital Input Operation**

A digital input is standard on the meter. This digital input is programmed identically to function keys F1, F2, and F3. The input is triggered with a contact closure between DI+ and DI-, or with an active low signal. During operation, the digital input operates according to the way it has been programmed in the *Advanced Features – User* menu.

# Maximum/Minimum Readings


The max & min readings (peak & valley) reached by the process can be displayed either continuously or momentarily.

Display momentarily by pressing the F1 function key (default) or assigning to any of the other function keys or to the digital input in the *User* menu.

Display continuously by pressing the *Enter* button while the max/min is being displayed to lock the display. Press *Enter* again to unlock.


Any of the F1-F3 function keys (buttons) and the digital input can be programmed to reset the max & min readings. The meters are set at the factory to display the max reading by pressing the *Right Arrow/F1* button and to use the *Up-Arrow/F2* button to access the *Reset* menu. Press the *Right Arrow* button to cycle through the available parameters to reset.

#### Top Display: Process Value Bottom Display: Max & Min




# Runtime & Cycle Count (INF[])

The relay information menu shows runtime and cycle count for each relay. These values may be cleared at any time by selecting the *Clear* option (<code>CLERR7</code>). If the cycle count or runtime values need to be changed on a frequent basis, it would be convenient to set up a CapTouch button or the digital input to simplify this process.



**Note:** See the menu tree under *Solid-State Relay Outputs* (RELRY) on page *44* for complete menu structure on this feature.



# Changing PV2 Engineering Units

It is possible to change PV2's display units within the selected unit class without the need to re-scale the meter. The UNITS menu in the DISPLAY menu allows the unit of measure to be changed (e.g. from gallons (GAL) to liters (L)) and the meter will automatically convert the display values to the new unit of measure. If entering a custom unit (CUSTCM), the input must be scaled using the custom unit. See *Changing the Engineering Units* (UNITS) on page 36.

# Troubleshooting

This product is a highly sophisticated instrument with an extensive list of features and capabilities. If the CapTouch buttons are used to program the meter, it can be a difficult task to keep everything straight. That is why we strongly recommend the use of the free <u>MeterView XL</u> software for all programming activities. A cable is provided to use the MeterView XL software for programming the meter.


If you have programmed the meter with the CapTouch buttons and it is not working as intended, try re-programming the meter using the MeterView XL software.

# **Reset Meter to Factory Defaults**

When the parameters have been changed in a way that is difficult to determine what's happening, it might be better to start the setup process from the factory defaults. This can be accomplished using MeterView XL software or with the CapTouch buttons.

To load factory defaults:

- 1. Press the *Menu* button to enter *Programming Mode*.
- 2. Press the *Right-Arrow* button twice and press *Enter* to access the *Advanced* menu.
- 3. Press the *Up-Arrow* button and press *Enter* to access the *System* menu.
- 4. Press the *Right-Arrow* button and press *Enter* to access the *Default* menu.
- Press *Enter* twice in quick succession. The meter will load default settings and restart.



### **Determining Software Version**

To determine the software (firmware) version of a meter:

- 1. Press the *Menu* button to enter *Programming Mode*.
- 2. Press the *Up-Arrow* button twice and press *Enter* to access the *Advanced* menu.
- 3. Press the *Up-Arrow* button and press *Enter* to access the *System* menu.
- 4. Press the *Up-Arrow* button twice and press *Enter* to access the *Info* menu.
- Press the *Right-Arrow* button to cycle through the meter information. When done, press the *Menu* button to return to the previous menu or press & hold *Menu* to exit to Run mode.

### **Factory Default Settings**

The following table shows the factory setting for most of the programmable parameters on the meter.

Parameter	Display	Default Setting		
	Input Menu			
Unit of Measure	UNIT	Feet & Inches		
Input 1	INP I	4.000 mA		
Display 1	15P (	0.00		
Input 2	IND 5	20.000 mA		
Display 2	15P 2	100.00		
	Output Menu			
Open Collector Output 1	OUTPUT I	Disabled		
Pulse Factor	FACTOR	1.0		
Test Frequency	FREQ	100		
Alarm	ALARM	PV		
Alarm Action	RETION	AUTO		
Set Point	SET	20.00		
Reset Point	RESET	10.00		
Alarm On Delay	Delay on	0 seconds		
Alarm Off Delay	DELAY OFF	0 seconds		
Alarm Fail-safe	FAILSAFE	OFF		
Red LED	RED	ON		
Flash PV	FLASH	ON		
Alarm Message	M56	ON		
Message Text	MSG EDIT	ALARM 1		
Timer Off Delay	OFF.DLAY	1 minute		
Timer On Time	ON TIME	1 second		
Timer Mode	MODE	Continuous		
Open Collector Output 2	0UTPUT 2	Disabled		
Set Point	SET	40.00		
Reset Point	RESET	30.00		
Message Text	MSG EDIT	ALARM 2		
Relay Output 1	RELAY I	Disabled		
Alarm	Alarm	PV		
Alarm Action	RETION	AUTO		
Set Point	SET	70.00		
Reset Point	RESET	60.00		
Alarm On Delay	Delay on	0 seconds		
Alarm Off Delay	DELAY OFF	0 seconds		
Alarm Fail-safe	FAILSAFE	OFF		
Red LED	RED	ON		
Flash PV	FLASH	ON		
Alarm Message	M56	ON		
Message Text	MSG EDIT	ALARM 3		

Parameter	Display	Default Setting
	Pump Control Menu	1
Pump Ctrl On		70.00
Pump Ctrl Off	OFF	60.00
Pump Ctrl On Delay	JELAY ON	0 seconds
Pump Ctrl Off Delay	DELAY OFF	0 seconds
Pump Alt On 1	ON I	70.00
Pump Alt Off 1	OFF I	60.00
Pump Alt On 2	ON 2	90.00
Pump Alt Off 2	0FF 2	80.00
Pump Alt On Delay 1	Delay Ion	0 seconds
Pump Alt Off Delay 1	DELAY IOFF	0 seconds
Pump Alt On Delay 2	JELAY 2 ON	0 seconds
Pump Alt Off Delay 2	JELAY 2 OFF	0 seconds
Timer Off Delay	OFF.DLAY	1 minute
Timer On Time	ON TIME	1 second
Timer Mode	MODE	Continuous
Relay Output 2	RELAY 2	Disabled
Set Point	SET	20.00
Reset Point	RESET	10.00
Message Text	MSG EDIT	ALARM 4
4-20 mA Output	4-20 mA	PV
	Advanced Menu	
Signal Conditioning Function	FUNETN	Linear (2 pts)
Low Cutoff	CUTOFF	Enabled: 0
Filter	FILTER	2.0 seconds
Filter Bypass	37682	0.4 PCT
Password	PR55WR]	00000 (Unlocked)
Function Key 1	F I	Display
Function Key 2	F2	Reset
Function Key 3	F3	Acknowledge
Digital Input	DI	Acknowledge
Hint Feature	HINT	Disabled
Dual-Scale	PV 2	Disabled
Backlight	BACKLITE	Enabled
CapTouch	САРТОЦЕН	Normal
-	Display Menu	
Unit of Measure	UNITS	FT-IN/* *auto-reducing fractions
Bargraph	JARGRAPH	Percent of PV
Bottom Display	BOTTOM	Tag (LEVEL)
	•	

# **Troubleshooting Tips**

Certain sequences of events can cause unexpected results. To solve these issues, it is best to start fresh from factory defaults and use the manual as a step by step programming guide, rather than a random approach to programming. To reset the meter to factory defaults, see *Factory Default Settings* on page 65. In addition, for best results, we recommend using the free <u>MeterView XL</u> software for all programming needs.

Symptom	Check/Action		
No display at all	<ol> <li>Check:</li> <li>The 4-20 mA current loop is providing at least 3.5 mA to the meter.</li> <li>The voltage drop of all devices connected to the 4-20 mA current loop does not exceed the max rating of the loop power supply.</li> </ol>		
Not able to change setup or programming, LCEKE1 is displayed	Meter is password-protected. Enter correct five-digit password to unlock or Master Password of 50865.		
Meter display flashes: 1. 99999 29999	Check that the number of digits required for the scaled value does not exceed the maximum digits for the display. If it does, try adjusting the decimal point location for less precision or changing the PV display to the bottom display.		
Display is unstable	Check: <ol> <li>Input signal stability and value.</li> <li>Display scaling vs. input signal.</li> <li>Filter and bypass values (increase).</li> </ol>		
Display response is too slow	Check filter and bypass values		
Display reading is not accurate	<ol> <li>Check:</li> <li>Input signal conditioner selected: Linear, square root, etc.</li> <li>Scaling or calibration</li> </ol>		
Display does not respond to input changes, reading a fixed number	Check display assignment. It might be displaying max, min, or set point.		
Display shows: 1. MRX and a number 2. MIN and a number	Press Menu to exit max/min display readings.		
Relay operation is reversed	Check fail-safe settings in Output menu		
Relays do not respond to signal	Check: <ol> <li>Relay action in <i>Output</i> menu</li> <li>Set and reset points</li> <li>Check manual control menu</li> </ol>		
If the display locks up or the meter does not respond at all	Cycle the power to reboot the microprocessor.		
CapTouch buttons do not respond	<ol> <li>If hand-symbol is flashing, multiple buttons were touch at the same time, wait a few seconds until the hand symbol goes off.</li> <li>If <i>Delayed</i> mode has been set, press &amp; hold any button for 5 seconds, the buttons should respond normally.</li> <li>If the slide switch on the display module is in the Lock position, move the switch to the Unlock position; see <i>Turning Off CapTouch Buttons</i> on page 25.</li> </ol>		
Other symptoms not described above	Call Technical Support for assistance.		

# **Complete Product Line of Loop-Powered Meters** WITH ALL THE SAME **FEATURES & FUNCTIONALITY**



Outputs



2 Solid-State

Relays



ANH

4-20 mA Output



Backlight



**Dual-Line** 

Displays



Control



Loop Leader+

# LARGE DISPLAY >>

PD4 Loop Leader+ Series

• NEMA 4X, IP65 Rated Wall-Mount Enclosures

Ex CE IECEX

- Large 5-Digit, 2.8" High Top Display
- · Safe Area and I.S. Models
- ATEX and IECEx Certified



JEFCISION



Protex W & Kx ( E IECEX

# EXPLOSION-PROOF $\otimes$

### PD6900 ProtEX+ Series

- NEMA 4X, IP68 Rated Aluminum and Stainless Steel Enclosures
- CapTouch Through-Glass Buttons
- Explosion-Proof & I.S.
- · UL Listed, CSA, ATEX, and IECEx Certified



# 1/8 DIN PANEL MOUNT 🔅

### PD6600 Loop Leader Series

- NEMA 4X, IP65 Rated Front 1/8 DIN Panel Mount Meters
- General Purpose and I.S. and N.I. Models
- UL, C-UL, and CE Approved

# VantageView+ (€

# FIELD-MOUNT 🔅

PD6900 VantageView+ Series

- NEMA 4X, IP66 Rated **Plastic Enclosure**
- CapTouch Through-Window **Buttons**
- General Purpose



MeterView XL Software Programs All These Products

# **Contact Precision Digital**

### **Technical Support**

Call: (800) 610-5239 or (508) 655-7300 Email: support@predig.com

# **Sales Support**

Call: (800) 343-1001 or (508) 655-7300 Email: sales@predig.com

### **Place Orders**

Email: orders@predig.com

# For the latest version of this manual please visit

www.predig.com

**PRECISION DIGITAL CORPORATION** 





LIM6907HA\_C SFT125 Ver 1.000 & up 04/24